

Compliance inspection report form

520 Lafayette Road North St. Paul, MN 55155-4194

Existing Subsurface Sewage Treatment System (SSTS)

Doc Type: Compliance and Enforcement

Instructions: Inspector must submit completed form to Local Governmental Unit (LGU) and system owner within 15 days of final determination of compliance or noncompliance. Instructions for filling out this form are located on the Minnesota Pollution Control Agency (MPCA) website at <u>https://www.pca.state.mn.us/sites/default/files/wq-wwists4-31a.pdf</u>.

Property information	Local tracking	number:		
Parcel ID# or Sec/Twp/Range: 2202920330002	Reason for Inspection	Property Transfer		
Local regulatory authority info: Washington County				
Property address: 2275 Overlook Ct N West Lakeland, Mn. 55082				
Owner/representative: Pete Boyum		Owner's phone: <u>651-336-5750</u>		
Brief system description: 1 septic tank and 1 lift tank to drainfield. West Lakeland Township or records of a		is system with Washington County or		

System status

System status on date (mm/dd/yyyy): 7/26/2022

Compliant – Certificate of compliance*

(Valid for 3 years from report date unless evidence of an imminent threat to public health or safety requiring removal and abatement under section 145A.04, subdivision 8 is discovered or a shorter time frame exists in Local Ordinance.)

*Note: Compliance indicates conformance with Minn. R. 7080.1500 as of system status date above and does not guarantee future performance.

Noncompliant – Notice of noncompliance

Systems failing to protect ground water must be upgraded, replaced, or use discontinued within the time required by local ordinance.

An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance or under section 145A.04 subdivision 8.

Reason(s) for noncompliance (check all applicable)

Impact on public health (Compliance component #1) - Imminent threat to public health and safety

Tank integrity (Compliance component #2) - Failing to protect groundwater

Other Compliance Conditions (Compliance component #3) - Imminent threat to public health and safety

Other Compliance Conditions (Compliance component #3) - Failing to protect groundwater

System not abandoned according to Minn. R. 7080.2500 (Compliance component #3) - Failing to protect groundwater

Soil separation (Compliance component #5) – Failing to protect groundwater

Operating permit/monitoring plan requirements (Compliance component #4) - Noncompliant - local ordinance applies

Comments or recommendations

Certification

I hereby certify that all the necessary information has been gathered to determine the compliance status of this system. No determination of future system performance has been nor can be made due to unknown conditions during system construction, possible abuse of the system, inadequate maintenance, or future water usage.

By typing my name below, I certify the above statements to be true and correct, to the best of my knowledge, and that this information can be used for the purpose of processing this form.

Business name: David R Brown		Certification number: 9370	
Inspector signature:	DRB	License number: 3649	
	(This document has been electronically signed)	Phone: 651-788-3296	

Necessary or locally required supporting documentation (must be attached)

Soil observation logs	System/As-Built	Locally required forms	Tank Integrity Assessment	Operating Permit
Other information (list):				

1. Impact on public health – Compliance component #1 of 5

Compliance criteria:			
System discharges sewage to the ground surface	□ Yes* 🖾 No		
System discharges sewage to drain tile or surface waters.	□ Yes* ⊠ No		
System causes sewage backup into dwelling or establishment.	🗆 Yes* 🛛 No		

Any "yes" answer above indicates the system is an imminent threat to public health and safety.

Describe verification methods and results:

Attached supporting documentation:

.

Other:
Ouler.

Not applicable

2. Tank integrity - Compliance component #2 of 5

Compliance criteria:		Attached supporting documentation:
System consists of a seepage pit, cesspool, drywell, leaching pit, or other pit?	□ Yes* ⊠ No	Empty tank(s) viewed by inspector Name of maintenance business: Apostle
Sewage tank(s) leak below their designed operating depth?	□ Yes* ⊠ No	License number of maintenance business: <u>23구4</u> Date of maintenance: 7/26/2022
		Existing tank integrity assessment (Attach)
If yes, which sewage tank(s) leaks:		Date of maintenance (mm/dd/yyyy): (must be within three years)
Any "yes" answer above indicates the system is failing to protect groundwater.		(See form instructions to ensure assessment complies with Minn. R. 7082.0700 subp. 4 B (1))
		Tank is Noncompliant (pumping not necessary – explain below)
		□ Other:
Describe verification methods and	results:	

3. Other compliance conditions – Compliance component #3 of 5

3	a. Maintenance hole covers appear to be structurally unsound (damaged, cracked, etc.), or uns	ecured?
	🗋 Yes* 🖾 No 📋 Unknown	
3	o. Other issues (electrical hazards, etc.) to immediately and adversely impact public health or safe	ty? 🗌 Yes* 🛛 No 🔲 Unknown
	*Yes to 3a or 3b - System is an imminent threat to public health and safety.	
3	c. System is non-protective of ground water for other conditions as determined by inspector?	🗌 Yes* 🛛 No
30	J. System not abandoned in accordance with Minn. R. 7080.2500?	🗋 Yes* 🖾 No
	*Yes to 3c or 3d - System is failing to protect groundwater.	
	Describe verification methods and results:	
	Attached supporting documentation:	
4. O	perating permit and nitrogen BMP* – Compliance component #4 c	of 5 M Not applicable
		If "yes", A below is required
Is	the system required to employ a Nitrogen BMP specified in the system design? Yes No	If "yes", B below is required
	BMP = Best Management Practice(s) specified in the system design	
	the answer to both questions is "no", this section does not need to be complete	d.
Co	ompliance criteria:	
	a. Have the operating permit requirements been met?	
	b. Is the required nitrogen BMP in place and properly functioning?	
	Any "no" answer indicates noncompliance.	
	Describe verification methods and results:	

Attached supporting documentation:
Operating permit (Attach)

5. Soil separation – Compliance component #5 of 5

Date of installation	(mm/dd/yyyy)	🛛 Unkr	iown			
Shoreland/Wellhead protection/Food beverage lodging? Compliance criteria (select one):		☐ Yes	🛛 No	Attached supporting documentation: Soil observation logs completed for the report Two previous verifications of required vertical separations		
5a. For systems built prior to April 1, 1996, and not located in Shoreland or Wellhead Protection Area or not serving a food, beverage or lodging establishment:		🗌 Yes	⊠ No*	 Not applicable (No soil treatment area) 		
Drainfield has at le separation distance saturated soil or be						
5b.Non-performance systems built April 1, 1996, or later or for non-		☐ Yes	No*	Indicate depths or elevations		
performance systems located in Shoreland or Wellhead Protection Areas or serving a			A. Bottom of distribution media	18"		
	lodging establishment:			B. Periodically saturated soil/bedrock	28" 10"	
Drainfield has a three-foot vertical separation distance from periodically saturated soil or bedrock.*				C. System separation D. Required compliance separation*	36"	
				*May be reduced up to 15 percent if allo Ordinance.		
systems built unde Type IV or V syste Rules 7080. 2350 (Intermediate Insp 2,500 gallons per d License required >	ms built under 2008 or 7080.2400 ector License required ≤ day; Advanced Inspector • 2,500 gallons per day) ne designed vertical e from periodically		□ No*			

*Any "no" answer above indicates the system is falling to protect groundwater.

Describe verification methods and results:

Upgrade requirements: (Minn. Stat. § 115.55) An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.

