usiness Name: SS Septic Solutions, LI	LC	Date: 8/10/2	2022
Soil separation - Complia	ince component #5	of 5	
Date of installation 3/1/1977 (mm/dd/yyyy)	☐ Unknown		
Shoreland/Wellhead protection/Fobeverage lodging?	ood Yes 🛭 No	Attached supporting documentation: ☑ Soil observation logs completed for the report	
Compliance criteria (select one):		☐ Two previous verifications of required vertical separation	
5a. For systems built prior to April 1,		☐ Not applicable (No soil treatment area)	
not located in Shoreland or Wellh Protection Area or not serving a t beverage or lodging establishme	food,		1
Drainfield has at least a two-foot separation distance from periodic saturated soil or bedrock.			
5b. Non-performance systems built April 1, 1996, or later or for non- performance systems located in Shoreland or Wellhead Protection Areas or serving a food, beverage, or lodging establishment: Drainfield has a three-foot vertical separation distance from periodically saturated soil or bedrock.*	☐ Yes ☐ No	Indicate depths or elevations	
	Shoreland	A. Bottom of distribution media 2	
	serving a	B. Periodically saturated soil/bedrock 2	
		C. System separation 0	
		D. Required compliance separation* 2	
		*May be reduced up to 15 percent if allowed Ordinance.	by Local
5c. "Experimental", "Other", or "Perfo systems built under pre-2008 Rul Type IV or V systems built under Rules 7080. 2350 or 7080.2400 (Intermediate Inspector License re 2,500 gallons per day; Advanced License required > 2,500 gallons Drainfield meets the designed ver separation distance from periodic saturated soil or bedrock.	es; 2008 equired ≤ Inspector per day) tical		

Upgrade requirements: (Minn. Stat. § 115.55) An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, repaired, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.