

520 Lafayette Road North St. Paul, MN 55155-4194

## Compliance Inspection Form

## **Existing Subsurface Sewage Treatment Systems (SSTS)**

Doc Type: Compliance and Enforcement

Inspection results based on Minnesota Pollution Control Agency (requirements and attached forms – additional local requirements may Submit completed form to Local Unit of Government (LUG) and within 15 days	also apply.
System Status	
ELI SINCE DE L'ANTINE L'ANT	
System status on date (mm/dd/yyyy): 4/20/2017  Compliant – Certificate of Compliance (Valid for 3 years from report date, unless shorter time frame outlined in Local Ordinance.)	Noncompliant – Notice of Noncompliance (See Upgrade Requirements on page 3.)
Reason(s) for noncompliance (check all applicable)  Impact on Public Health (Compliance Component #1) – Imminen  Other Compliance Conditions (Compliance Component  Tank Integrity (Compliance Component #2) – Failing to  Other Compliance Conditions (Compliance Component  Soil Separation (Compliance Component #4) – Failing to  Operating permit/monitoring plan requirements (Compliance Component)	#3) – Imminent threat to public health and safety protect groundwater #3) – Failing to protect groundwater p protect groundwater
Property Information Parcel ID:	# on Coo/Tour/Double   40 004 00 04 0000
Property address: 12744 150 <sup>th</sup> St N Marine on St. Croix, MN 5504	# or Sec/Twp/Range: 16.031.20.34.0002
Property owner: Irene Elkins or	Owner's phone: 651-275-9476
Owner's representative:	Representative phone:
Local regulatory authority: Washington County	Regulatory authority phone: 651-430-6673
Brief system description: 2 1000 gallon septic tanks & 576 SF gr	
Comments or recommendations:	avity, rock trendit draitilield.
Certification	
I hereby certify that all the necessary information has been gathered determination of future system performance has been nor can be mapossible abuse of the system, inadequate maintenance, or future was	ade due to unknown conditions during system construction.
Inspector name: Tom Trooien	Certification number: 323
Business name: All State Septic Services LLC	License number: 1568
Inspector signature: Jor Tro-	Phone number: <u>612-594-4496</u>
Necessary or Locally Required Attachments	_
<ul><li>☑ Soil boring logs</li><li>☑ System/As-built drawing</li><li>☑ Other information (list):</li></ul>	☐ Forms per local ordinance

Property address: <u>12744 150th St N Marine or</u>	St. Croix, MN 55047	Inspector initials/Date: _	TT   4/20/2017 (mm/dd/yyyy)
4. Soil Separation Compliance co	omponent #4 of 5		(
Date of installation: 10/11/1993 (mm/dd/yyyy)  Shoreland/Wellhead protection/Food beverage lodging?  Compliance criteria:	Unknown	Verification method(s):	
	⊠ Yes □ No	Soil observation does not expire. Previous soil observations by two independent parties are sufficient, unless site conditions have been altered or local requirements differ.	
For systems built prior to April 1, 1996, and not located in Shoreland or Wellhead Protection Area or not serving a food, beverage or lodging establishment:  Drainfield has at least a two-foot vertical separation distance from periodically saturated soil or bedrock.	☐ Yes ☐ No	<ul> <li>☐ Conducted soil observation(s) (Attach boring logs)</li> <li>☐ Two previous verifications (Attach boring logs)</li> <li>☐ Not applicable (Holding tank(s), no drainfield)</li> <li>☐ Unable to verify (See Comments/Explanation)</li> <li>☐ Other (See Comments/Explanation)</li> <li>Comments/Explanation:</li> <li>0-13 sandy silt loam</li></ul>	
Non-performance systems built April 1, 1996, or later or for non-performance systems located in Shoreland or Wellhead Protection Areas or serving a food, beverage, or lodging establishment:  Drainfield has a three-foot vertical separation distance from periodically saturated soil or bedrock.*	⊠ Yes □ No		
"Experimental", "Other", or "Performance" systems built under pre-2008 Rules; Type IV or V systems built under 2008 Rules (7080. 2350 or 7080.2400 (Advanced Inspector License required)	☐ Yes ☐ No	A. Bottom of distribution media  B. Periodically saturated soil/bedrock	24-42
Drainfield meets the designed vertical separation distance from periodically saturated soil or bedrock.		C. System separation	38
Any "no" answer above indicates the failing to protect groundwater.  5. Operating Permit and Nitrogen		D. Required compliance separation*  *May be reduced up to 15 percent if Ordinance.  Ce component #5 of 5	36 allowed by Local
Is the system operated under an Operating Is the system required to employ a Nitroger  BMP = Best Management Practice(s) s	Permit? Yes	<ul><li>☒ No</li><li>☒ If "yes", A below is require</li><li>☒ No</li><li>☒ If "yes", B below is require</li></ul>	ed
If the answer to both questions is "n  Compliance criteria	o", this section doe	es not need to be completed.	

Any "no" answer indicates Noncompliance.

Have the Operating Permit requirements been met?

b. Is the required nitrogen BMP in place and properly functioning?

a. Operating Permit number: n/a

Upgrade Requirements (Minn. Stat. § 115.55) An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, repaired, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.

☐ Yes ☐ No

☐ Yes ☐ No

www.pca.state.mn.us • 651-296-6300 • TTY 651-282-5332 or 800-657-3864 • Available in alternative formats 800-657-3864 wq-wwists4-31b . 6/4/14 Page 3 of 3

