



333 Main Street NW
P.O. Box 388
Elk River, MN 55330
Phone: 763-441-7509
Fax: 763-441-9176

DRINKING WATER LABORATORY TEST REPORT

Last Name: WINEGAR **File #:** 73271
First Name: DAVID **Date/Time**
Address: 910 MARK AVE N **in Lab:** 9/2/2022 10:00 AM
City: WEST LAKELAND **Unique Well #:**
State: MN **Zip Code:** **Drillers #:**
County:
Legal:

Ordered By: SS SEPTIC SOLUTIONS **Sampled From:** Outside Tap
Sampled By: SS SEPTIC SOLUTIONS **Date/Time Sampled:** 09/01/2022 1100
Reason For Test: Coliform + Nitrate **Sample Temp:** 26.0 ° C
Received on Ice: No

<u>ANALYTE & METHOD</u>	<u>DATE & TIME OF ANALYSIS</u>	<u>MAXIMUM CONTAMINATION LEVEL (EPA)</u>	<u>TEST RESULTS</u>
Coliform Bacteria (SM 9223 B)	09/02/2022 1400	Negative	Negative
Nitrate (EPA 353.2 Rev 2.0)	09/02/2022 1326	10.0 ppm	< 0.5 ppm

This sample DOES meet EPA guidelines for safe drinking water for the Analytes tested.

Notes:

The test results are only indicative of the sample tested from the sample point on the date collected.
This report must not be reproduced, except in full, without the written approval from Water Laboratories, Inc.
Minnesota Certification# 027-141-110, Wisconsin Certification #399044470 (for compliance with NR812)

Water Laboratories, Inc.

By: 

Date: 09/06/2022

Received By CW Entered By TJ Edited By TJ

Amount Billed:

Date Paid: 09/02/2022

Amount Paid: