

## SSTS MAINTENANCE REPORT

System Location			
Address	6795 Orchard Ridge Trail		Telephone Number
City	Woodbury	State	ZIP 55125 Property ID No./GEO Code
Owner	Elizabeth Runnoco	Pumping Date	7/13/16
Contractor			
Maintainer	Boss Pumping	MPCA License No.	1945 Telephone Number (651) 466-0800


What was done to the system?
<input checked="" type="checkbox"/> Tank(s) Pumped
<input type="checkbox"/> Sludge and scum measured.
Do tanks need to be pumped?
<input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements below)

Report Liquid Capacity in Gallons					
Tank 1:	1000	<input checked="" type="checkbox"/> Pumped	Tank 2:	1000	<input checked="" type="checkbox"/> Pumped
Tank 3:		<input type="checkbox"/> Pumped	Tank 4:		<input type="checkbox"/> Pumped
Total Gallons Pumped:		2000			

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

*Tank Measurements-Use Only If Tank(s) Were NOT Pumped							
Tank Length	_____ in.	<input checked="" type="checkbox"/> Tank Width	_____ in.	<input checked="" type="checkbox"/> Tank Depth	_____ in.	= Tank Volume (cubic inches)	_____
Tank Radius	_____ in.	<input checked="" type="checkbox"/> Tank Radius	_____ in.	<input checked="" type="checkbox"/> 3.14	= Tank Volume (cubic inches)	_____	
Tank Volume (cu. in.)	/ 231.01 = Liquid Capacity		_____ Gallons/	Tank Depth	_____ in.	= Gallons/Inch	_____
Sludge Level	_____ in.	<input checked="" type="checkbox"/> Gallons Per Inch	_____ = Sludge Volume	Gallons			
Scum Level	_____ in.	<input checked="" type="checkbox"/> Gallons Per Inch	_____ = Scum Volume	Gallons			
Sludge Volume	_____ +	Scum Volume	_____ = Total Sludge and Scum Volume	Gallons			
Total Sludge and Scum Volume	_____ /	Liquid Capacity	_____ = Percent Sludge and Scum in Tank	%			



Scum Layer

Effluent

Sludge Layer

Tank Depth measured from invert of outlet pipe to bottom of tank

\*Tanks must be pumped if either of the following conditions exist:  
 1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or  
 2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Signature



Date

7-13-16

Reset Form