

pd chk
 \$16.00

SSTS MAINTENANCE REPORT

System Location		
Address	8130 KIMBRO AVE SO	Telephone Number 651-459-5402
City	COTTAGE GROVE	State MN, ZIP 55016 Property ID No./GEO Code
Owner	LAWRENCE GERLACH	Pumping Date
Contractor		
Maintainer	MPCA License No.	Telephone Number

What was done to the system?

Tank(s) Pumped

Sludge and scum measured. Do tanks need to be pumped?

Yes No (If no provide measurements below)

Report Liquid Capacity in Gallons

Tank 1: _____ Pumped Tank 2: _____ Pumped

Tank 3: _____ Pumped Tank 4: _____ Pumped

Total Gallons Pumped: _____

Visual Inspection (note any problems with the system):


NOTE: This does not serve as a compliance inspection.

***Tank Measurements-Use Only If Tank(s) Were NOT Pumped**

Liquid Level of Tank (Distance from invert of outlet pipe to bottom of tank): 54 in.

Sludge Level 4 in. + Scum Level 0 in. = Total Sludge and Scum Level 4 in.

Total Sludge and Scum Level _____ in. / Liquid Level _____ in. = Sludge and Scum percent in Tank _____ %



*Tanks must be pumped if either of the following conditions exist:

1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

RECEIVED
 AUG 17 2016
 PUBLIC HEALTH

Signature

Lawrence Gerlach

Date:

8-15-16

\$16.00 processing fee

Make checks payables and remit to:

Washington County Public Health and Environment
 14949 62nd St N
 Stillwater, MN 55082