

SSTS MAINTENANCE REPORT

System Location		
Address	1877 QUARTZ AVE SO., LAKELAND, MN 55043 Telephone Number 651-808-0697	
City	LAKELAND	State MN ZIP 55043 Property ID No./GEO Code U.029.20.34.0072
Owner	MICHAEL J. & MARIE B. GILMER Date	
Contractor		
Maintainer	MPCA License No.	Telephone Number

What was done to the system?

Tank(s) Pumped

Sludge and scum measured. Do tanks need to be pumped?

Yes No (If no provide measurements below)

Report Liquid Capacity in Gallons

Tank 1: _____ Pumped Tank 2: _____ Pumped

Tank 3: _____ Pumped Tank 4: _____ Pumped

Total Gallons Pumped: _____

Visual Inspection (note any problems with the system):


NOTE: This does not serve as a compliance inspection.

***Tank Measurements-Use Only If Tank(s) Were NOT Pumped**

Liquid Level of Tank (Distance from invert of outlet pipe to bottom of tank: 57 in.

Sludge Level < 2 in. + Scum Level < 1 in. = Total Sludge and Scum Level 3 in.

Total Sludge and Scum Level 3 in. / Liquid Level 57 in. = Sludge and Scum percent in Tank 5.3 %



*Tanks must be pumped if either of the following conditions exist:

1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

RECEIVED
AUG 18 2016
PUBLIC HEALTH

Signature Michael J. Gilmer

Date: 8/17/2016

2015
\$17.00 Processing Fee
 Make Checks payables and remit to:
 Washington County Public Health and Environment
 14949 62nd St N
 Stillwater, MN 55082