

520 Lafayette Road North St. Paul, MN 55155-4194

## Compliance Inspection Form

## **Existing Subsurface Sewage Treatment Systems (SSTS)**

Doc Type: Compliance and Enforcement

Inspection results based on Minnesota Pollution Confrequirements and attached forms – additional local requirements		For local tracking purposes:			
Submit completed form to Local Unit of Governmen within 15 days	t (LUG) and system owner				
System Status					
System status on date (mm/dd/yyyy): 8/29/20	016				
○ Compliant – Certificate of Compliant     (Valid for 3 years from report date, unless shorter frame outlined in Local Ordinance.)		liant – Notice of Noncompliance Requirements on page 3.)			
Reason(s) for noncompliance (check all a	pplicable)				
☐ Impact on Public Health (Compliance Comp		public health and safety			
☐ Other Compliance Conditions (Compliance		**************************************			
☐ Tank Integrity (Compliance Component #2)					
☐ Other Compliance Conditions (Compliance					
☐ Soil Separation (Compliance Component #4	4) - Failing to protect groundwa	ater			
Operating permit/monitoring plan requireme	ents (Compliance Component #	‡5) – Noncompliant			
Property Information  Property address: 14777 110 <sup>th</sup> . St. S, Hastings, Mn. 5  Property owner: Clark Tufte		ge: _3302720110005 for inspection: _property transfer phone: 612-710-4401			
or	Owner s	priorie012-710-4401			
Owner's representative:	Represer	ntative phone:			
Local regulatory authority: Washington County	Regulato	Regulatory authority phone: 651-430-6655			
Brief system description: 1-1200 gal. precast septic to	ank, 1000 gal. precast pump ta	ank and approx. 300 lin. ft. rock drainfied.			
Comments or recommendations:					
Existing records from Wash. Co. indicate system was indefinitely a pre 1996 system.	stalled sometime in 1988. I am	using 5/22/1988 as an installation date. It is			
Certification					
I hereby certify that all the necessary information has be determination of future system performance has been no possible abuse of the system, inadequate maintenance,	or can be made due to unknow	compliance status of this system. No in conditions during system construction,			
Inspector name: Roger Benson	Certificat	ion number: 1505			
Business name: Benson Septic Service	Licer	nse number: 190			
Inspector signature: Kozerio Ba	Pho	one number: 651-438-9910			
Necessary or Locally Required Attachme	ents				
_	_	11			
Soil boring logs System/As-built draw	wing	local ordinance			
Other information (list):					

Inspector initials/Date: Rob | 8/29/2016 (mm/dd/yyyy)

1.	Impact	on	Public	Health -	<ul> <li>Compliance</li> </ul>	component #1	of 5
----	--------	----	--------	----------	--------------------------------	--------------	------

٠.	impact off rabile ricater - c	compliance compor	1611(#1010			
	Compliance criteria:		Verification method(s):			
	System discharges sewage to the ground surface.	☐ Yes ⊠ No	<ul> <li>✓ Searched for surface outlet</li> <li>✓ Searched for seeping in yard/backup in home</li> </ul>			
	System discharges sewage to drain tile or surface waters.	☐ Yes ☒ No	☐ Excessive ponding in soil system/D-boxes ☐ Homeowner testimony (See Comments/Explanation)			
	System causes sewage backup into dwelling or establishment.	☐ Yes ☒ No	☐ "Black soil" above soil dispersal system ☐ System requires "emergency" pumping			
	Any "yes" answer above indi system is an imminent threat health and safety.		☐ Performed dye test ☐ Unable to verify (See Comments/Explanation) ☐ Other methods not listed (See Comments/Explanation)			
	Comments/Explanation: No black soil above pipe. Effluent level in drop boxes normal.  Tank Integrity — Compliance	component #2 of 5				
	Compliance criteria:		Verification method(s):			
	System consists of a seepage pit, cesspool, drywell, or leaching pit.	☐ Yes ⊠ No	<ul> <li>☑ Probed tank(s) bottom</li> <li>☐ Examined construction records</li> </ul>			
	Seepage pits meeting 7080.2550 may be compliant if allowed in local ordinance.		☐ Examined Tank Integrity Form (Attach)			
	Sewage tank(s) leak below their designed operating depth.  If yes, which sewage tank(s) leaks:	☐ Yes ⊠ No	<ul> <li>☐ Observed liquid level below operating depth</li> <li>☐ Examined empty (pumped) tanks(s)</li> <li>☐ Probed outside tank(s) for "black soil"</li> </ul>			
	Any "yes" answer above indi system is failing to protect gi		<ul> <li>☐ Unable to verify (See Comments/Explanation)</li> <li>☐ Other methods not listed (See Comments/Explanation)</li> </ul>			
	Comments/Explanation: Effluent levels in tanks normal.					
3.	Other Compliance Condition	ns – Compliance com	ponent #3 of 5			
	. Maintenance hole covers are damaged, cracked, unsecured, or appear to be structurally unsound. ☐ Yes* ☒ No ☐ Unknown					
	b. Other issues (electrical hazards, etc.) *System is an imminent threat to		ersely impact public health or safety.			
	Explain:					
	c. System is non-protective of ground *System is failing to protect ground	water for other condition	ns as determined by inspector . ☐ Yes* ☒ No			
	Explain:					

www.pca.state.mn.us • 651-296-6300 • 800-657-3864 • TTY 651-282-5332 or 800-657-3864 • Available in alternative formats wq-wwists4-31b • 6/4/14

failing to protect groundwater.

Ordinance.

5.	Operating Permit and Nitrogen BMP*	<ul> <li>Compliance com</li> </ul>	ponent #5 of 5	Not applicable     ■		
	Is the system operated under an Operating Permit?  Is the system required to employ a Nitrogen BMP?  BMP = Best Management Practice(s) specified	☐ Yes ☐ No	If "yes", A below is If "yes", B below is			
	If the answer to both questions is "no", this section does not need to be completed.  Compliance criteria					
	Operating Permit number:     Have the Operating Permit requirements been	met?	☐ Yes ☐ No			

Any "no" answer indicates Noncompliance.

b. Is the required nitrogen BMP in place and properly functioning?

Upgrade Requirements (Minn. Stat. § 115.55) An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, repaired, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.

☐ Yes ☐ No

TTY 651-282-5332 or 800-657-3864 • Available in alternative formats 651-296-6300 800-657-3864 www.pca.state.mn.us • Page 3 of 3 14777 110th St. S. Hastings, Ma 55033 -N-

~1200 gol septic +ANK 1000 gal pump tank Compliance BOR. NS 19-38" 10x2 4/3 514 10AM 38-50" 10 xx 4/3 SANDY LOAM 50-54" 10 yr 5/4 SANDY LOAM

RW B---