



Subsurface Sewage Treatment System Maintenance Permit

This section must be completed in its entirety to constitute a valid maintenance permit. This permit must be completed prior to performing maintenance activities and remain on-site for the duration of the maintenance activity.

Date of Maintenance: 10/09/2023 Reason for Maintenance: General Service
 Property Address: 19900 Maxwell Ave Property Owner's Name: Thomas Owczarzak
 Municipality: Moline on St. Croix ZIP: 55047 Property Identification Number: _____
 Maintenance Permit No: _____ Maintainer Name and License No. Northside Septic Service, LLC/L930

Maintenance Performed	Tank Measurement (must be completed if tanks NOT pumped)
<input checked="" type="checkbox"/> Tank(s) Pumped <input checked="" type="checkbox"/> Sludge and scum measured Do tanks need to be pumped? <input type="checkbox"/> Yes <input type="checkbox"/> No (if no provide measurements)	Liquid Level of Tank <u>43</u> in Sludge Level in Tank <u>13</u> in Scum Level in Tank <u>0</u> in Sludge + Scum <u>19</u> / Liquid Level <u>43</u> X 100 = % Sludge & Scum <u>44</u> Tanks must be pumped if 25% or greater

- Access used to remove septage: Maintenance Hole Other (enter authorization code)
- Were all covers securely replaced? Yes No
- Is there evidence of tank leakage from a septic, holding, pretreatment or pump tank below the operating depth or evidence of damaged, cracked, or structurally unsound maintenance hole covers? NO

Tank	Leaking Out	Leaking In	Cover Damage
Septic/Holding Tank #1	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Septic/Holding Tank #2	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Pretreatment Tank	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Pump Tank	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

- How many gallons of septage were removed?
 Tank #1 1250 gal Tank #2 1250 gal Pretreatment tank _____ gal Pump Tank 200 gal
- Other information: List any troubleshooting, minor repairs conducted, tank safety concerns, or other concerns.
Cleaned dirty effluent filter
- Location of septage disposal: Isanti County

*Jake
or
Kyle*

Northside Septic Service, LLC
 1301 245th Ave NE
 Bethel, MN 55005
 License# 930 P: 763-444-7898 ✓

RECEIVED
OCT 26 2023
PUBLIC HEALTH