

520 Lafayette Road North St. Paul, MN 55155-4194

Compliance inspection report form

Existing Subsurface Sewage Treatment System (SSTS)

Doc Type: Compliance and Enforcement

Inst	tru	cti	0	ns	1000
					1

Instructions for filling out this form are located on the Minnesota Pollution

Control Agency (MPCA) website at								
Property information	Local tracking number:							
Parcel ID# or Sec/Twp/Range: 1503020130006	Reason for Inspection Sale of property							
Local regulatory authority info: Washington County								
Property address: 9633 PAWNEE AVE N, TOWN OF STILLW	ATER .							
Owner/representative: GAG ROSEMARY J & THOMAS J	Owner's phone: 651-439-0225							
Brief system description: Single septic tank gravity fed to drain t	field							
System status								
System status on date (mm/dd/yyyy):11/3/2023								
□ Compliant – Certificate of compliance*	☐ Noncompliant – Notice of noncompliance							
(Valid for 3 years from report date unless evidence of an imminent threat to public health or safety requiring removal and	Systems failing to protect ground water must be upgraded, replaced, or use discontinued within the time required by local ordinance.							
abatement under section 145A.04, subdivision 8 is discovered or a shorter time frame exists in Local Ordinance.)	An imminent threat to public health and safety (ITPHS) must be							
*Note: Compliance indicates conformance with Minn. R. 7080.1500 as of system status date above and does not guarantee future performance.	upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance or under section 145A.04 subdivision 8.							
Reason(s) for noncompliance (check all applicat	ole)							
☐ Impact on public health (Compliance component #1)								
☐ Tank integrity (Compliance component #2) – Failing								
☐ Other Compliance Conditions (Compliance component								
☐ Other Compliance Conditions (Compliance component								
	2500 (Compliance component #3) – Failing to protect groundwater							
Soil separation (Compliance component #5) – Failin								
	npliance component #4) – Noncompliant - local ordinance applies							
Comments or recommendations	inplication deline in ity interior inplication in the application in the interior in the inter							
Certification								
future system performance has been nor can be made due to unknown inadequate maintenance, or future water usage.	to determine the compliance status of this system. No determination of wn conditions during system construction, possible abuse of the system,							
By typing my name below, I certify the above statements to be true used for the purpose of processing this form.	and correct, to the best of my knowledge, and that this information can be							
Business name: SS Septic Solutions, LLC.	Certification number: 9917							
Inspector signature:	License number: 4137							
This document has been electronically sign	ned) Phone: 651-343-9117							
Necessary or locally required supporting do	cumentation							
☐ Soil observation logs ☐ System/As-Built ☐ Locally re	equired forms							
☐ Other information (list):								
https://www.pca.state.mn.us • 651-296-6300 • 800-657-386	 Use your preferred relay service Available in alternative formats 							

ompliance criteria:		Attached supporting documentation:
ystem discharges sewage to the round surface	☐ Yes ⊠ No	☐ Other: ☐ Not applicable
ystem discharges sewage to drain e or surface waters.	☐ Yes ⊠ No	
ystem causes sewage backup into welling or establishment.	☐ Yes ⊠ No	
escribe verification methods and	l results:	
k integrity – Compliance	component#	2 of 5
Compliance criteria:		Attached supporting documentation:
System consists of a seepage pit,	☐ Yes ⊠ No	☐ Empty tank(s) viewed by inspector
esspool, drywell, leaching pit,		
er other pit? Sewage tank(s) leak below their	☐ Yes ⊠ No	Name of maintenance business: License number of maintenance business:
or other pit?		Name of maintenance business: License number of maintenance business: Date of maintenance:
Sewage tank(s) leak below their lesigned operating depth?		Name of maintenance business: License number of maintenance business: Date of maintenance: Existing tank integrity assessment (Attach) Date of maintenance 11/1/2023
er other pit? Sewage tank(s) leak below their		Name of maintenance business: License number of maintenance business: Date of maintenance: Existing tank integrity assessment (Attach) Date of maintenance 11/1/2023 (mm/dd/yyyy): (must be within three years) (See form instructions to ensure assessment complies within three within three years)
Sewage tank(s) leak below their lesigned operating depth?		Name of maintenance business: License number of maintenance business: Date of maintenance: Existing tank integrity assessment (Attach) Date of maintenance 11/1/2023 (mm/dd/yyyy): (must be within three years)

Property Address: 9633 PAWNEE AVE N, TOWN OF STILLWATER

	Property Address: 9633 PAWNEE AVE N, TOWN OF STILLWATER Susiness Name: SS Septic Solutions, LLC.	D-4-	11/2/2022
fixe	TO COPIG COIGIONS, ELC.	Date:	11/3/2023
2	Other compliance conditions Compliance company 42 - fr		
<i>.</i>]	Other compliance conditions – Compliance component #3 of 5		
	3a. Maintenance hole covers appear to be structurally unsound (damaged, cracked, etc.), or unsec ☐ Yes ☑ No ☐ Unknown	ured?	
	3b. Other issues (electrical hazards, etc.) to immediately and adversely impact public health or safety	? Yes	⊠ No □ Unknown
	3c. System is non-protective of ground water for other conditions as determined by inspector?	☐ Yes	⊠ No
	3d. System not abandoned in accordance with Minn. R. 7080.2500?	☐ Yes	⊠ No
	Describe verification methods and results:		
			28
			334
	Attached supporting documentation: Not applicable		
4.	Operating permit and nitrogen BMP* – Compliance component #4 of	5 × 1	Not applicable
	Is the system operated under an Operating Permit? ☐ Yes ☐ No If	"yes", A	below is required
	Is the system required to employ a Nitrogen BMP specified in the system design? ☐ Yes ☐ No If	"yes", B	below is required
	BMP = Best Management Practice(s) specified in the system design	53	
95	If the answer to both questions is "no", this section does not need to be completed.		
	Compliance criteria:		16
	a. Have the operating permit requirements been met?		
	b. Is the required nitrogen BMP in place and properly functioning? Yes No		
	Describe verification methods and results:		
	Attached aumanting decrees antation.		
	Attached supporting documentation: Operating permit (Attach)		

Business Name: SS Septic Solutions, LLC.			Date:	1/3/2023
Soil separation – Compliance con	nponent	:#5 o	f 5	
Date of installation 12/3/1991 (mm/dd/yyyy)	☐ Unknow	vn		
Shoreland/Wellhead protection/Food beverage lodging?	☐Yes ∑	☑ No	Attached supporting documentation:	±1
neverage roughly:			Soil observation logs completed for the	e report
Compliance criteria (select one):		075	☐ Two previous verifications of required	vertical separation
5a.For systems built prior to April 1, 1996, and not located in Shoreland or Wellhead Protection Area or not serving a food, beverage or lodging establishment:	⊠ Yes □] No	☐ Not applicable (No soil treatment area	a)
Drainfield has at least a two-foot vertical separation distance from periodically saturated soil or bedrock.				
5b. Non-performance systems built	☐ Yes ☐] No	Indicate depths or elevations	
April 1, 1996, or later or for non- performance systems located in Shoreland			A. Bottom of distribution media	24"
or Wellhead Protection Areas or serving a			B. Periodically saturated soil/bedrock	60"
food, beverage, or lodging establishment: Drainfield has a three-foot vertical			C. System separation	36"
separation distance from periodically			D. Required compliance separation*	24"
saturated soil or bedrock.*			*May be reduced up to 15 percent if allo Ordinance.	owed by Local
5c. "Experimental", "Other", or "Performance" systems built under pre-2008 Rules; Type IV or V systems built under 2008 Rules 7080. 2350 or 7080.2400 (Intermediate Inspector License required ≤ 2,500 gallons per day; Advanced Inspector License required > 2,500 gallons per day)	☐ Yes □	No		
Drainfield meets the designed vertical separation distance from periodically saturated soil or bedrock.				

Describe verification methods and results:

Upgrade requirements: (Minn. Stat. § 115.55) An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, repaired, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.

Property address: 103 Powned 13 City: Stringer	State: 1/2	Parcel ID: Zip code; 云头公子
Optional section: Sewage Tank Compliance C This form does not represent a complete system incomplete.	ertification (Tank int	egrity assessment)
This form does not represent a complete system inspection this form, completed, may serve as a tank integrity assessment. Instructions: This section of the form may be completed and sig Maintenance Business who personally conducts the necessary protection the system. When this section of the form is signed by a qualified certified professing System Compliance Inspection Report: Compliance Inspection on the MPCA website at https://www.poc.el-bt.	ned by a Designated Certified ocedures to assess the compli	Individual (DCI) of a licensed SSTS ance status of each sewage tank in
Existing System Compliance Inspection Report: Compliance Inspection Gound on the MPCA website at https://www.pca.state.mn.us/water/ The information and certified statement on this form is required water/ individual other than the SSTS Inspector that submits an inspection component compliance and is allowable under Minn. R. 7082.0706 three years beyond the signature date on this form unless a new expective according to local regulations. Additional Administrative R. 7082.0700, subp. 4 items B, C, and D; 7083.0730 Item C.	hen existing septic tank compline of the complination of the compl	ance status is determined by an a third party assessment of SSTS
Affirm all three statements: The SSTS does not contain a seepage pit, cesspool, drywell, leaching pit, or other pit. It does not contain a sewage tank that was designed to be watertight, but subsequently leaks below the designed operating depth. It does not represent an imminent safety threat by reason of unsecured, damaged, or weak maintenance hole cover(s) or other unsafe condition.	Select all that apply: The SSTS has a selecting pit, or oth Groundwater." It has a sewage to watertight, but sub operating depthoperating d	seepage pit, cesspool, drywell, ner pit – "Failure to Protect ank that was designed to be sequently leaks below the designed "Failure to Protect Groundwater." It to public safety by reason of led, or weak maintenance hole usafe condition.
company information ompany name: Usiness license number: personally conducted the work described above as a Designated Courses. I personally conducted the necessary procedures to assess typping/signing my name below, I certify the above statements his information can be used for the purpose of processing this formation can be used for the purpose of processing this formation can be used for the purpose of processing this formation can be used for the purpose of processing this formation can be used for the purpose of processing this formation.	Designated Certified In Print name: Certification number: Certified Individual of a Minness ss the compliance status of ea to be true and correct, to the b	

vation Obser Soil

v 03.15.2023	9633 Pawnee Ave.	Organic Matter Disturbed/Fill	Flooding/Run-On potential:	e Elevai	Limiting Layer Elevation:	Auger	Structure	e Grade Consistence		5		בל ס		ב סמ								#) (Date) signature below represents an infield verification of	
ct D:	Address:	um Bedrock	Linear, Linear	Surfac		Observation Type:	H 5	Shape Shape		מ ב		5 5 7	§	รี				+		and laws.	4137	0500 subp. 3 A. The	
CION LOS Project	Location /	Lacustrine Loess Till Alluvium	Stope shape:	ap units: 454B0	Cool - cloudy			Cotor (s) Redox hind(s) III												ith all applicable ordinances, rules	Hamble States	(Signature) verified according to Minn. R. 7082.	
II ODSELVa	ose Gag	y) [3] Outwash	% adols	Soil survey ma	11/3/2023 2:00			x cotor (s) mottle	R 3/3		R 4/4		R 3/4							rk in acodrdance w		soil observation was	proposed soil treatm
000	Tom & R	sck all that appl	Back/Side Slope	Grass	Conditions:	See Map	Rock	Frag. % Maul	107	2	10V	2	10V	2						completed this wo		y certify that this	r bedrock at
		material(s): (Check	Position: B	5	of Day/Weather	n #/Location:		exme	Medium	Loamy Sand	Loamy	Coarse Sand	Pues Care	במו אל המו						that I have	schlon	Designer/Inspector) Verification: I hereby	saturated soil
	Client:	Soil parent m	Landscape Po	Vegetation:	Date/Time of	Observation	Don'th /in)		α · C		0" 71"	† '	"	r .					Comments:	hereby certify	She	(Designer/ Optional Verification	the periodically

GARAGE 1500 GAILON SEPTIC CIEANOUT

SS Septic Solutions, LLC additional terms and information.

- 1. SS Septic Solutions, LLC has not been retained to warrant, guarantee, or certify the proper functioning of the system for any period beyond the inspection date. Due to numerous factors (usage, maintenance, tank pumping, soil characteristics, previous failures, etc.) which may affect the proper operation of a septic system. The report shall not be construed as a warranty that the system will properly function for any period.
- 2. Minimum compliance inspection requirements relative to this inspection and this report include only verification that the septic system has a watertight septic tank(s) and lift tank, the required separation from the bottom of the drain field/mound distribution medium and saturated soils, no backup of sewage into the dwelling and no discharge of sewage onto the ground surface or surface water. SS Septic Solutions, LLC does not inspect basement sewage ejector pumps or exterior lift pumps as they are a maintenance item. Sewage backup verification is limited to the information supplied by the last occupants/owner if available. I cannot guarantee that the information given to me is accurate. Some people may attempt to hide or conceal signs of previous backups.
- 3. Certification of this system does not warranty any future use beyond the date of inspection.

 Any system, new or old, can be hydraulically overloaded because of more people moving into the house than were previously occupying it, improper maintenance, heavy usage, tree roots, freezing conditions, or surface drainage problems. The system could simply stop working due to age.
- 4. A compliance inspection is not meant to be a test of the longevity of the septic system. The inspection is strictly for the purpose of determining if the septic is polluting the environment at the date and time the inspection is performed. The inspection is not intended to determine if the system was originally designed or installed to past or present MPCA or local unit of government code requirements.
- 5. Winter Work Client understands that inspections conducted in winter weather conditions are more difficult to perform due to snow cover and frost. Septic system components like tanks, tank covers, drop boxes and soil treatment areas are more difficult to locate in these conditions. Soil borings and drain field locations are also more difficult to perform due to ground frost. The client needs to understand that due to the weather conditions, the same level of standards may not be possible compared to an inspection during the spring/summer/fall months.
- 6. If hired to perform the compliance inspection, the client hereby agrees that SS Septic Solutions, LLC will not be responsible for any monetary damages, claims or causes of action including attorney fees arising from the performance of this inspection.
- 7. Nothing other than gray water (laundry, showers, etc.) human waste and toilet tissue should be disposed of into the septic tanks. Garbage disposals are not recommended. Smaller amounts of laundry, soaps, dish soap, cleaning agents, etc. are better for the system. Antibacterial soaps and chlorine agents may kill the bacteria needed to treat effluent properly. Additives are not recommended and may be harmful to your system. Recommend to pump and clean your tanks by a certified pumper every other year if you have 1 tank and every 2-3 years if you have a 2-tank system to ensure proper maintenance.