

UID 50724  
J 3808633997

# Subsurface Sewage Treatment System Maintenance Permit

Property/Owner Information Permit #: \_\_\_\_\_ (pumping code)

Complete in its entirety to constitute a valid maintenance permit. This permit must be completed prior to performing maintenance activities and remain on-site for the duration of the maintenance activity.

Date of Maintenance: 10-12-23 Property ID #: \_\_\_\_\_

Property Address: 8460 150<sup>th</sup> St. N Hugo MN 53038  
Street Address City State Zip

Property Owner Name: Roland Stricklin

## Maintenance Performed

- Tanks Pumped:
- Emergency
  - Home Sale
  - High-level alarm
  - Routine/Maintenance
  - Compliance Inspection
  - Repair
  - Other: \_\_\_\_\_

OR

Sludge and Scum Measured: (must be completed if tanks NOT pumped)

Liquid Level of Tank: \_\_\_\_\_ in Sludge Level: \_\_\_\_\_ in

Scum Level: \_\_\_\_\_ in

Sludge+Scum/ \_\_\_\_\_ Liquid Level \_\_\_\_\_ x100= \_\_\_\_\_ %Sludge & Scum

**Tanks must be Pumped if 25% or greater**

## Maintenance Information

Were all covers securely replaced?  Yes  No If No, Explain: \_\_\_\_\_

Is the tank designed as a leaky? Ex. Seepage pit, cesspool drywell leaching pit NO

Tank #1:  Yes  No Verification Method Used: Visual Gallons Removed: 1500

Leaking Out:  Yes  No Leaking In:  Yes  No Cover Damaged:  Yes  No

Tank #2:  Yes  No Verification Method Used: Visual Gallons Removed: None

Leaking Out:  Yes  No Leaking In:  Yes  No Cover Damaged:  Yes  No

Tank #3:  Yes  No Verification Method Used: \_\_\_\_\_ Gallons Removed: \_\_\_\_\_

Leaking Out:  Yes  No Leaking In:  Yes  No Cover Damaged:  Yes  No

Tank #4:  Yes  No Verification Method Used: \_\_\_\_\_ Gallons Removed: \_\_\_\_\_

Leaking Out:  Yes  No Leaking In:  Yes  No Cover Damaged:  Yes  No

Pump Tank:  Yes  No Verification Method Used: Visual Gallons Removed: NONE

Leaking Out:  Yes  No Leaking In:  Yes  No Cover Damaged:  Yes  No

Waste Disposal Method:  Treatment plant  Land Apply: Location 21.10589.03

Other remarks or Concerns: customer only wanted 1st tank pumped.

## Maintainer Information

Maintainer Name: Sherco Construction, Inc.  
Maintainer Address: 79 North Lake Street Forest Lake, MN 55025  
Phone Number: (651) 462-1817

Maintainer Signature: Joseph Lemf

License Number: L1675

I hereby certify as a State of Minnesota certified SSTS Maintainer that I personally conducted the work and made the observations, or directly supervised others in the performance of this job.

**Maintenance activities must be reported to the Department within 90 days.**



Sent client copy