

SSTS MAINTENANCE REPORT

System Location			
Address	5405 240th st	Telephone Number	(612) 499-2907
City	Forest Lake	State Mn ZIP	55025 Property ID No./GEO Code
Owner	Peter Riesgraf	Pumping Date	Sep 22, 2016
Contractor			
Maintainer	Row Sewer Service	MPCA License No.	L3309 Telephone Number (651) 465-5505


What was done to the system?
<input checked="" type="checkbox"/> Tank(s) Pumped
<input type="checkbox"/> Sludge and scum measured.
Do tanks need to be pumped?
<input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements below)

Report Liquid Capacity in Gallons					
Tank 1:	1,250	<input checked="" type="checkbox"/> Pumped	Tank 2:	300	<input checked="" type="checkbox"/> Pumped
Tank 3:		<input type="checkbox"/> Pumped	Tank 4:		<input type="checkbox"/> Pumped
Total Gallons Pumped: 1,550					

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

*Tank Measurements-Use Only If Tank(s) Were NOT Pumped					
Tank Length	_____ in.	<input checked="" type="checkbox"/> Tank Width	_____ in. <input checked="" type="checkbox"/> Tank Depth	_____ in. = Tank Volume (cubic inches)	_____
Tank Radius	_____ in.	<input checked="" type="checkbox"/> Tank Radius	_____ in. <input checked="" type="checkbox"/> 3.14 =	Tank Volume (cubic inches)	_____
Tank Volume (cu. in.)	_____ / 231.01 =	Liquid Capacity	_____ Gallons /	Tank Depth	_____ in. = Gallons/Inch
Sludge Level	_____ in. <input checked="" type="checkbox"/> Gallons Per Inch	_____ =	Sludge Volume	_____ Gallons	
Scum Level	_____ in. <input checked="" type="checkbox"/> Gallons Per Inch	_____ =	Scum Volume	_____ Gallons	
Sludge Volume	_____ +	Scum Volume	_____ =	Total Sludge and Scum Volume	_____ Gallons
Total Sludge and Scum Volume	_____ /	Liquid Capacity	_____ =	Percent Sludge and Scum in Tank	_____ %



Scum Layer

Effluent

Sludge Layer

Tank Depth measured from invert of outlet pipe to bottom of tank

*Tanks must be pumped if either of the following conditions exist:
 1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
 2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Signature *[Handwritten Signature]*

Date 9/22/16

Reset Form