

520 Lafayette Road North St. Paul, MN 55155-4194

# Compliance inspection report form

## Existing Subsurface Sewage Treatment System (SSTS)

Doc Type: Compliance and Enforcement

#### Instructions:

Instructions for filling out this form are located on the Minnesota Pollution

Control Agency (MPCA) website at		
Property information	Local tracking	number:
Parcel ID# or Sec/Twp/Range: 3502920330011  Local regulatory authority info: Washington County	Reason for Inspection	Transfer of deed
Property address: 16060 QUALITY CT S, CITY OF LAKELAND	)	
Owner/representative: Dustin Finn		Owner's phone: 612-438-8724
Brief system description: 1500 gallon Septic tank 1000 gallon pu	imp tank to in ground drain	field
System status		
System status on date (mm/dd/yyyy): 11/21/2024		
□ Compliant – Certificate of compliance*	☐ Noncompliant – Noti	ce of noncompliance
(Valid for 3 years from report date unless evidence of an imminent threat to public health or safety requiring removal and abatement under section 145A.04, subdivision 8 is discovered or a shorter time frame exists in Local Ordinance.)	use discontinued within the to An imminent threat to public	ound water must be upgraded, replaced, or ime required by local ordinance.  health and safety (ITPHS) must be se discontinued within ten months of receipt
*Note: Compliance indicates conformance with Minn. R. 7080.1500 as of system status date above and does not guarantee future performance.	of this notice or within a should under section 145A.04 subd	rter period if required by local ordinance or
Reason(s) for noncompliance (check all applicate   Impact on public health (Compliance component #1)   Tank integrity (Compliance component #2) - Failing   Other Compliance Conditions (Compliance component   Other Compliance Conditions (Compliance component   System not abandoned according to Minn. R. 7080.   Soil separation (Compliance component #5) - Failing   Operating permit/monitoring plan requirements (Comments or recommendations	- Imminent threat to public to protect groundwater ent #3) - Imminent threat to ent #3) - Failing to protect g 2500 (Compliance compone g to protect groundwater	public health and safety roundwater ent #3) – Failing to protect groundwater
I hereby certify that all the necessary information has been gathered future system performance has been nor can be made due to unknown inadequate maintenance, or future water usage.  By typing my name below, I certify the above statements to be true used for the purpose of processing this form.	wn conditions during system o	onstruction, possible abuse of the system,
Business name: SS Septic Solutions, LLC.		Certification number: 9917
Inspector signature: Shelley Schlomka		License number: 4137
(This document has been electronically sig	ned)	Phone: 651-343-9117
Necessary or locally required supporting do	xumentation	
☐ Soil observation logs ☐ System/As-Built ☐ Locally I	required forms	egrity Assessment
☐ Other information (list):		

800-657-3864

ess Name: SS Septic Solutions, LLC.	odnýkonský žijemi ne prie kypeny výmo výmo vymo venejým.		Date:	11/21/2024
pact on public health – Co	omplia	nce com	onent #1 of 5	
Compliance criteria:			Attached supporting documentation	on:
System discharges sewage to the ground surface	☐ Yes	⊠ No	☐ Other: ☐ Not applicable	
System discharges sewage to drain tile or surface waters.	☐ Yes	⊠ No		
System causes sewage backup into dwelling or establishment.	☐ Yes	⊠ No		
Describe verification methods and	d results:			
nk integrity – Compliance	e comp	onent #2		
Compliance criteria:	≥ comp	onent #2	Attached supporting documentation	
				on: Schiomka's
Compliance criteria:  System consists of a seepage pit, cesspool, drywell, leaching pit, or other pit?  Sewage tank(s) leak below their		₩ No	Attached supporting documentation    Empty tank(s) viewed by inspector	Schlomka's
Compliance criteria:  System consists of a seepage pit, cesspool, drywell, leaching pit, or other pit?	III Yes	₩ No	Attached supporting documentation	Schlomka's
Compliance criteria:  System consists of a seepage pit, cesspool, drywell, leaching pit, or other pit?  Sewage tank(s) leak below their	III Yes	₩ No	Attached supporting documentation  Empty tank(s) viewed by inspector  Name of maintenance business:  License number of maintenance business	Schlomka's ness:
Compliance criteria:  System consists of a seepage pit, cesspool, drywell, leaching pit, or other pit?  Sewage tank(s) leak below their	I Yes	₩ No	Attached supporting documentation  Empty tank(s) viewed by inspector  Name of maintenance business:  License number of maintenance business:  Date of maintenance:  Existing tank integrity assessment (All Date of maintenance)	Schlomka's ness:
Compliance criteria:  System consists of a seepage pit, cesspool, drywell, leaching pit, or other pit?  Sewage tank(s) leak below their designed operating depth?	I Yes	₩ No	Attached supporting documentation  Empty tank(s) viewed by inspector  Name of maintenance business:  License number of maintenance business:  Date of maintenance:  Existing tank integrity assessment (All Date of maintenance)	Schlomka's ness: 11/21/2024 ttach) thin three years)
Compliance criteria:  System consists of a seepage pit, cesspool, drywell, leaching pit, or other pit?  Sewage tank(s) leak below their designed operating depth?	I Yes	₩ No	Attached supporting documentation  Empty tank(s) viewed by inspector  Name of maintenance business:  License number of maintenance business:  Date of maintenance:  Existing tank integrity assessment (After Date of maintenance (mm/dd/yyyy): (must be with Care of maintenance)  (See form instructions to ensure assessment)	Schlomka's ness: 11/21/2024 ttach) thin three years) ssment complies w

	roperty Address: 16060 QUALITY CT S, CITY OF LAKELAND usiness Name: SS Septic Solutions, LLC.	Date: 11/21/2024
٠,		
3.	Other compliance conditions – Compliance component #3 of 5	
	3a. Maintenance hole covers appear to be structurally unsound (damaged, cracked, etc.), or unsecu ☐ Yes ☑ No ☐ Unknown	ured?
	3b. Other issues (electrical hazards, etc.) to immediately and adversely impact public health or safety?	? ☐ Yes ⊠ No ☐ Unknown
	3c. System is non-protective of ground water for other conditions as determined by inspector?	☐ Yes 図 No
	3d. System not abandoned in accordance with Minn. R. 7080.2500?	☐ Yes 図 No
	Describe verification methods and results:	
	Attached supporting documentation:   Not applicable	
4.	Operating permit and nitrogen BMP* – Compliance component #4 of	5 Not applicable
	Is the system operated under an Operating Permit? ☐ Yes ☐ No If	"yes", A below is required
	Is the system required to employ a Nitrogen BMP specified in the system design? ☐ Yes ☐ No If	"yes", B below is required
	BMP = Best Management Practice(s) specified in the system design	
	If the answer to both questions is "no", this section does not need to be completed.	
	Compliance criteria:	
	a. Have the operating permit requirements been met? ☐ Yes ☐ No	
	b. Is the required nitrogen BMP in place and properly functioning? ☐ Yes ☐ No	
	Describe verification methods and results:	
	Attached supporting documentation:   Operating permit (Attach)	

roperty Address: 16060 QUALITY CT S, CITY Cousiness Name: SS Septic Solutions, LLC.			Date: 11	1/21/2024				
Soil separation – Compliance con	npone	nt #5 o	f 5					
Date of installation 8/1/1987 (mm/dd/yyyy)	☐ Unkn	own						
Shoreland/Wellhead protection/Food beverage lodging?	☐ Yes	⊠ No	Attached supporting documentation:	e report				
Compliance criteria (select one):			☐ Two previous verifications of required					
	⊠ Yes	□ No	☐ Not applicable (No soil treatment area					
Drainfield has at least a two-foot vertical separation distance from periodically saturated soil or bedrock.								
5b. Non-performance systems built	□Yes		Indicate depths or elevations					
April 1, 1996, or later or for non- performance systems located in Shoreland			A. Bottom of distribution media	5'				
or Wellhead Protection Areas or serving a food, beverage, or lodging establishment:			B. Periodically saturated soil/bedrock	2' - 3'				
Drainfield has a three-foot vertical	And the second s		C. System separation	2'				
separation distance from periodically			D. Required compliance separation*	2'				
saturated soil or bedrock.*	Conformation and an arrangement of the contract of the contrac		*May be reduced up to 15 percent if allo Ordinance.	wed by Local				
5c. "Experimental", "Other", or "Performance" systems built under pre-2008 Rules; Type IV or V systems built under 2008 Rules 7080. 2350 or 7080.2400 (Intermediate Inspector License required ≤ 2,500 gallons per day; Advanced Inspector License required > 2,500 gallons per day)  Drainfield meets the designed vertical separation distance from periodically saturated soil or bedrock.	Yes							

Describe verification methods and results:

Upgrade requirements: (Minn. Stat. § 115.55) An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, repaired, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.

Use your preferred relay service
 Available in alternative formats

v 03.15.2023	16060 Quality Court South	Matter Disturbed/Fill	Flooding/Rum-On potential:	levation-Relative to benchmark:	Limiting Layer Elevation:		Structure Structure of the second of the sec	Grade												11/21/2024	ire below represents an infield verification of		(Date)	
		Bedrock Organic	x, Convex	Surface Eleva		ation Type:		Share											SWS.	4.13.7	ubb, 3 A. The signatt		(Cert #)	AND THE PERSON NAMED IN
Project D:	ion / Address:	Aluvum	Comvex			Observe													, rules and lay		7082,0500 sur			
	Locat	Loess	Slope shape:		24 45 degrees														able ordinances		rding to Minn. R.	site.		
		Lacustrine	.9%		11/21/20	See Map													with all applica	シスと	(Signature)	The Amand dispe	(Signature)	The second section is the second second
		TSBWIIO TO	Stope	Soil survey n	Part Sun														reactor///aince		observation w	posed soil treat		Management of the Control of the Con
	Dustin Fir	that apply)			ions:		1 4		7.5VR		7.5YR								ed this work		that this soil	r bedrock at the pro		
		(Check all	Shoulder	Lawn	er Conditions:	0.5	Rock	Frag. %						OR CAROLES WALLES					completed	Q	THE RESERVE OF THE PERSON NAMED IN COLUMN TWO IS NOT THE PERSON NAMED IN COLUMN TWO IS NAMED IN COLUMN TW	i or bed	sctor)	11227
		material(s): (C	Position:		of Day/Weather	m #/Location:		3	Wedium	Loamy Sand	Media	Sandy Loam		www.watsawija					y that I have	Shelley Schlomka	Designer/Inspector)	saturate	(LGU/Designer/Inspector)	
	Client:	Soil parent n	Landscape P	Vegetation:	Date/Time o	Observation		Depth (in)		<b>T</b> 7.5	1.72	·						Comments:	I hereby certif	Š	Ontional Veri	the periodically		A how have top ? How

WE11 HOUSE GANAGE X-SOIL BORING 1500 Oppion SEPHIC

QUAlity -

### SS Septic Solutions, LLC additional terms and information.

- 1. SS Septic Solutions, LLC has not been retained to warrant, guarantee, or certify the proper functioning of the system for any period beyond the inspection date. Due to numerous factors (usage, maintenance, tank pumping, soil characteristics, previous failures, etc.) which may affect the proper operation of a septic system. This report shall not be construed as a warranty that the system will properly function for any period.
- 2. Minimum compliance inspection requirements relative to this inspection and this report include only verification that the septic system has a watertight septic tank(s) and lift tank, the required separation from the bottom of the drain field/mound distribution medium and saturated soils, no backup of sewage into the dwelling and no discharge of sewage onto the ground surface or surface water. SS Septic Solutions, LLC does not inspect basement sewage ejector pumps or exterior lift pumps as they are a maintenance item. Sewage backup verification is limited to the information supplied by the last occupants/owner if available. I cannot guarantee that the information given to me is accurate. Some people may attempt to hide or conceal signs of previous backups.
- 3. Certification of this system does not warranty any future use beyond the date of inspection. Any system, new or old, can be hydraulically overloaded because of more people moving into the house than were previously occupying it, improper maintenance, heavy usage, tree roots, freezing conditions, or surface drainage problems. The system could simply stop working due to age.
- 4. A compliance inspection is not meant to be a test of the longevity of the septic system. The inspection is strictly for the purpose of determining if the septic is polluting the environment at the date and time the inspection is performed. The inspection is not intended to determine if the system was originally designed or installed to past or present MPCA or local unit of government code requirements.
- 5. Winter Work Client understands that inspections conducted in winter weather conditions are more difficult to perform due to snow cover and frost. Septic system components like tanks, tank covers, drop boxes and soil treatment areas are more difficult to locate in these conditions. Soil borings and drain field locations are also more difficult to perform due to ground frost. The client needs to understand that due to the weather conditions, the same level of standards may not be possible compared to an inspection during the spring/summer/fall months.
- 6. If hired to perform the compliance inspection, the client hereby agrees that SS Septic Solutions, LLC will not be responsible for any monetary damages, claims or causes of action including attorney fees arising from the performance of this inspection.
- 7. Nothing other than gray water (laundry, showers, etc.) human waste and toilet tissue should be disposed of into the septic tanks. **Garbage disposals are not recommended**. Smaller amounts of laundry, soaps, dish soap, cleaning agents, etc. are better for the system. Antibacterial soaps and chlorine agents may kill the bacteria needed to treat effluent properly. Additives are not recommended and may be harmful to your system. Recommend to pump and clean your tanks by a certified pumper every other year if you have 1 tank and every 2-3 years if you have a 2-tank system to ensure proper maintenance. NEVER flush wipes (even if they state they are flushable) or any sanitary products. If they reach the drain field, they could cause it to fail.