

## SSTS MAINTENANCE REPORT

System Location		
Address	9735 Miller Rd So	Telephone Number 459-4437
City	Cottage Grove	State Mn ZIP 55016 Property ID No./GEO Code
Owner	Ervin Kopren	Pumping Date
Contractor		
Maintainer	MPCA License No.	Telephone Number

**What was done to the system?**

Tank(s) Pumped

Sludge and scum measured. Do tanks need to be pumped?

Yes  No (If no provide measurements below)

**Report Liquid Capacity in Gallons**

Tank 1: \_\_\_\_\_  Pumped    Tank 2: \_\_\_\_\_  Pumped

Tank 3: \_\_\_\_\_  Pumped    Tank 4: \_\_\_\_\_  Pumped

Total Gallons Pumped: \_\_\_\_\_

Visual Inspection (note any problems with the system):


NOTE: This does not serve as a compliance inspection.

**\*Tank Measurements-Use Only If Tank(s) Were NOT Pumped**

Liquid Level of Tank (Distance from invert of outlet pipe to bottom of tank: 3'4 1/2 in.

Sludge Level 5 in. + Scum Level 7/16" in. = Total Sludge and Scum Level 5 7/16 in.

Total Sludge and Scum Level 5" in. / Liquid Level 3'4" in. = Sludge and Scum percent in Tank \_\_\_\_\_ %



\*Tanks must be pumped if either of the following conditions exist:

1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Signature Ervin Kopren

Date: Dec - 1 - 16

**RECEIVED**

DEC 05 2016

**PUBLIC HEALTH**

2016

**\$17.00 Processing Fee**

Make Checks payables and remit to:  
 Washington County Public Health and Environment  
 14949 62nd St N  
 Stillwater, MN 55082