

DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT GOVERNMENT CENTER

14949 62nd STREET NORTH P.O. BOX 6 STILLWATER, MN 55082-0006 Office: 651-430-6655 TDD: 651-430-6246 FAX: 651-430-6730

SSTS MAINTENANCE REPORT

System Location	
Address 21049 Meadowh	
City Scandia	State MA) ZIP 55073 Property ID No./GEO Code
Owner Anthony Quevedo	Pumping Date 9~23-16
Contractor	
Maintainer R&M Septic	MPCA License No. 77083070 Telephone Number (651) 674-8520
What was done to the system?	Report Liquid Capacity in Gallons
Tank(s) Pumped Sludge and scum measured. Do tanks need to be pumped? Yes No (If no provide measurements be	Tank 1: 150 Pumped Tank 2: 1000 Pumped Tank 3: 750 Pumped Tank 4: Pumped Total Gallons Pumped: 2250
Visual Inspection (note any problems with the	e system): NOTE: This does not serve as a compliance inspection.
*Tank Measurements-Use Only If Tank(s) Were NOT Pumped	
Tank Length in. X Tank Width	in. X Tank Depth in. = Tank Volume (cubic inches)
Tank Radius in. X Tank Radius in. X 3.14 = Tank Volume (cubic inches)	
Tank Volume (cu. in.) / 231.01 = L	iquid Capacity Gallons / Tank Depth in. = Gallons/Inch
Sludge Level in. X Gallons Per Inch	= Sludge Volume Gallons
Scum Level in. X Gallons Per Inch	= Scum Volume Gallons
Sludge Volume + Scum Volume	= Total Sludge and Scum Volume Gallons
Total Sludge and Scum Volume / Li	quid Capacity = Percent Sludge and Scum in Tank %
Scum Layer Effluent Sludge Layer	*Tanks must be pumped if either of the following conditions exist: 1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or 2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.
Signature Ruchand (lim	Date 9-23-16 Reset Form