



DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT
 GOVERNMENT CENTER
 14949 62nd STREET NORTH P.O. BOX 6 STILLWATER, MN 55082-0006
 Office: 651-430-6655 TTY: 651-430-6246 FAX: 651-430-6730

Subsurface Sewage Treatment System Maintenance Permit

This section must be completed in its entirety to constitute a valid maintenance permit. This permit must be completed prior to performing maintenance activities and remain on-site for the duration of the maintenance activity.

Date of Maintenance: 10-17-14 Reason for Maintenance: Cleaning
 Property Address: 18225 Imperial Ave N Property Owner's Name: Chris Tocchio
 Municipality: Forest Lake ZIP: 55025 Property Identification Number: _____
 Maintenance Permit No: 6693063976 Maintainer Name and License No. Smilie's Sewer Service/L2428

Maintenance Performed	Tank Measurement (must be completed if tanks NOT pumped)
<input checked="" type="checkbox"/> Tank(s) Pumped <input type="checkbox"/> Sludge and scum measured Do tanks need to be pumped? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No (if no provide measurements)	Liquid Level of Tank _____ in Sludge Level in Tank _____ in Scum Level in Tank _____ in Sludge + Scum _____ / Liquid Level _____ X 100 = % Sludge & Scum _____ Tanks must be pumped if 25% or greater

- Access used to remove septage: Maintenance Hole Other (enter authorization code) _____
- Were all covers securely replaced? Yes No
- Is there evidence of tank leakage from a septic, holding, pretreatment or pump tank below the operating depth or evidence of damaged, cracked, or structurally unsound maintenance hole covers?

Tank	Leaking Out	Leaking In	Cover Damage
Septic/Holding Tank #1	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> NO	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> NO	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> NO
Septic/Holding Tank #2	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> NO	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> NO	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> NO
Pretreatment Tank	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Pump Tank	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> NO	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> NO	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> NO

- How many gallons of septage were removed?
 Tank #1 1,250 gal Tank #2 1,250 gal Pretreatment tank _____ gal Pump Tank 300 gal
- Other information: List any troubleshooting, minor repairs conducted, tank safety concerns, or other concerns.

6. Location of septage disposal: _____

Maintenance activities must be reported to the Department within 90 days.