

## Chris LeClair

---

**From:** Gary Bruns  
**Sent:** Thursday, April 27, 2017 12:30 PM  
**To:** Chris LeClair  
**Subject:** RE: 13851 23rd Street N

Ok.

---

**From:** Chris LeClair  
**Sent:** Thursday, April 27, 2017 11:44 AM  
**To:** Gary Bruns  
**Subject:** Re: 13851 23rd Street N

Yes, it looks like there are two drainfields. Brian is saying the 1976 system has 36" of separation, but is fully ponded and the "1980's" system, which is actually the 1993 system, has no separation.

---

**From:** Gary Bruns  
**Sent:** Thursday, April 27, 2017 11:35 AM  
**To:** Chris LeClair  
**Subject:** RE: 13851 23rd Street N

Hi Chris-

The paperwork on this says it's a 1993 replacement/ addition by Rick Fuhr?

-Gary

---

**From:** Chris LeClair  
**Sent:** Thursday, April 27, 2017 9:12 AM  
**To:** Gary Bruns  
**Subject:** 13851 23rd Street N

<https://septic.co.washington.mn.us/view.php?id=8237>

41 year old drainfield.

Not sure it would be worth our time to go out on this one.

**CHRISTOPHER W. LECLAIR, R.E.H.S.**

Sr. Environmental Specialist  
Washington County Department of  
Public Health & Environment  
651-430-4052  
[Chris.LeClair@co.washington.mn.us](mailto:Chris.LeClair@co.washington.mn.us)