

## SSTS MAINTENANCE REPORT

System Location		
Address <u>9595 Sulep TR</u>	Telephone Number	
City <u>Scandia</u>	State	ZIP
Owner <u>Ron Bettner</u>	Pumping Date <u>12-1-15</u>	Property ID No./GEO Code
Contractor		
Maintainer <u>Olsons Sewer</u>	MPCA License No.	Telephone Number <u>651-469-2682</u>

**What was done to the system?**

Tank(s) Pumped

Sludge and scum measured.

Do tanks need to be pumped?

Yes  No (If no provide measurements below)

**Report Liquid Capacity in Gallons**

Tank 1: 1200  Pumped Tank 2: 150  Pumped

Tank 3: \_\_\_\_\_  Pumped Tank 4: \_\_\_\_\_  Pumped

Total Gallons Pumped: 1350

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

**\*Tank Measurements Use Only if Tank(s) Were NOT Pumped**

Tank Length \_\_\_\_\_ in.  Tank Width \_\_\_\_\_ in.  Tank Depth \_\_\_\_\_ in. = Tank Volume (cubic inches) \_\_\_\_\_

Tank Radius \_\_\_\_\_ in.  Tank Radius \_\_\_\_\_ in.  **3.14** = Tank Volume (cubic inches) \_\_\_\_\_


Tank Volume (cu. in.) \_\_\_\_\_ / **231.01** = Liquid Capacity \_\_\_\_\_ Gallons / Tank Depth \_\_\_\_\_ in. = Gallons/Inch \_\_\_\_\_

Sludge Level \_\_\_\_\_ in.  Gallons Per Inch \_\_\_\_\_ = Sludge Volume \_\_\_\_\_ Gallons

Scum Level \_\_\_\_\_ in.  Gallons Per Inch \_\_\_\_\_ = Scum Volume \_\_\_\_\_ Gallons

Sludge Volume \_\_\_\_\_ + Scum Volume \_\_\_\_\_ = Total Sludge and Scum Volume \_\_\_\_\_ Gallons

Total Sludge and Scum Volume \_\_\_\_\_ / Liquid Capacity \_\_\_\_\_ = Percent Sludge and Scum in Tank \_\_\_\_\_ %



Scum Layer

Effluent

Sludge Layer

Tank Depth measured from invert of outlet pipe to bottom of tank

\*Tanks must be pumped if either of the following conditions exist:

1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Signature [Signature]

Date 12-1-15

Reset Form