



Minnesota Pollution Control Agency

520 Lafayette Road North
St. Paul, MN 55155-4194

Compliance Inspection Form
Existing Subsurface Sewage Treatment Systems (SSTS)

Doc Type: Compliance and Enforcement

Inspection results based on Minnesota Pollution Control Agency (MPCA) requirements and attached forms - additional local requirements may also apply.

Submit completed form to Local Unit of Government (LUG) and system owner within 15 days

For local tracking purposes:

System Status

System status on date (mm/dd/yyyy): 5/24/2017

[X] Compliant - Certificate of Compliance
(Valid for 3 years from report date, unless shorter time frame outlined in Local Ordinance.)

[ ] Noncompliant - Notice of Noncompliance
(See Upgrade Requirements on page 3.)

Reason(s) for noncompliance (check all applicable)

- [ ] Impact on Public Health (Compliance Component #1) - Imminent threat to public health and safety
[ ] Other Compliance Conditions (Compliance Component #3) - Imminent threat to public health and safety
[ ] Tank Integrity (Compliance Component #2) - Failing to protect groundwater
[ ] Other Compliance Conditions (Compliance Component #3) - Failing to protect groundwater
[ ] Soil Separation (Compliance Component #4) - Failing to protect groundwater
[ ] Operating permit/monitoring plan requirements (Compliance Component #5) - Noncompliant

Property Information

Parcel ID# or Sec/Twp/Range:

Property address: 9080 170th St N Hugo, MN 55038

Reason for inspection: Sale

Property owner: David and Dana Olmstead

Owner's phone: 612-802-5483

or

Owner's representative:

Representative phone:

Local regulatory authority: Washington County

Regulatory authority phone: 651-430-6000

Brief system description: 1250 gallon septic tank, 1000 gallon septic tank, 1000 gallon lift station, mound dispersal system

Comments or recommendations:

System failed compliance in 2013 due to an issue with the alarm system - this was fixed and certified by the county 8/28/2013. System functioning with no issues during this inspection.

Certification

I hereby certify that all the necessary information has been gathered to determine the compliance status of this system. No determination of future system performance has been nor can be made due to unknown conditions during system construction, possible abuse of the system, inadequate maintenance, or future water usage.

Inspector name: Benjamin Zierke

Certification number: 9594

Business name: Zierke Soil Testing

License number: 119

Inspector signature: [Signature]

Phone number: 651-249-1346

Necessary or Locally Required Attachments

- [X] Soil boring logs [X] System/As-built drawing [ ] Forms per local ordinance
[ ] Other information (list):

**1. Impact on Public Health – Compliance component #1 of 5**

**Compliance criteria:**

System discharges sewage to the ground surface.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
System discharges sewage to drain tile or surface waters.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
System causes sewage backup into dwelling or establishment.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

**Any "yes" answer above indicates the system is an imminent threat to public health and safety.**

**Comments/Explanation:**

Homeowners did not report any issues with the system.

**Verification method(s):**

- Searched for surface outlet
- Searched for seeping in yard/backup in home
- Excessive ponding in soil system/D-boxes
- Homeowner testimony (See Comments/Explanation)
- "Black soil" above soil dispersal system
- System requires "emergency" pumping
- Performed dye test
- Unable to verify (See Comments/Explanation)
- Other methods not listed (See Comments/Explanation)

**2. Tank Integrity – Compliance component #2 of 5**

**Compliance criteria:**

System consists of a seepage pit, cesspool, drywell, or leaching pit. <i>Seepage pits meeting 7080.2550 may be compliant if allowed in local ordinance.</i>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Sewage tank(s) leak below their designed operating depth. If yes, which sewage tank(s) leaks:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

**Any "yes" answer above indicates the system is failing to protect groundwater.**

**Comments/Explanation:**

Tanks pumped by Olson's 5/22/2017. See attached.

**Verification method(s):**

- Probed tank(s) bottom
- Examined construction records
- Examined Tank Integrity Form (Attach)
- Observed liquid level below operating depth
- Examined empty (pumped) tanks(s)
- Probed outside tank(s) for "black soil"
- Unable to verify (See Comments/Explanation)
- Other methods not listed (See Comments/Explanation)

**3. Other Compliance Conditions – Compliance component #3 of 5**

- a. Maintenance hole covers are damaged, cracked, unsecured, or appear to be structurally unsound.  Yes\*  No  Unknown
- b. Other issues (electrical hazards, etc.) to immediately and adversely impact public health or safety.  Yes\*  No  Unknown  
**\*System is an imminent threat to public health and safety.**

Explain:

- c. System is non-protective of ground water for other conditions as determined by inspector.  Yes\*  No  
**\*System is failing to protect groundwater.**

Explain:

**4. Soil Separation – Compliance component #4 of 5**

Date of installation: 7/7/2005  Unknown  
(mm/dd/yyyy)

Shoreland/Wellhead protection/Food beverage lodging?  Yes  No

**Compliance criteria:**

For systems built prior to April 1, 1996, and not located in Shoreland or Wellhead Protection Area or not serving a food, beverage or lodging establishment:	<input type="checkbox"/> Yes <input type="checkbox"/> No
Drainfield has at least a two-foot vertical separation distance from periodically saturated soil or bedrock.	
Non-performance systems built April 1, 1996, or later or for non-performance systems located in Shoreland or Wellhead Protection Areas or serving a food, beverage, or lodging establishment:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Drainfield has a three-foot vertical separation distance from periodically saturated soil or bedrock.*	
"Experimental", "Other", or "Performance" systems built under pre-2008 Rules; Type IV or V systems built under 2008 Rules (7080.2350 or 7080.2400 (Advanced Inspector License required)	<input type="checkbox"/> Yes <input type="checkbox"/> No
Drainfield meets the designed vertical separation distance from periodically saturated soil or bedrock.	

**Verification method(s):**

Soil observation does not expire. Previous soil observations by two independent parties are sufficient, unless site conditions have been altered or local requirements differ.

- Conducted soil observation(s) (Attach boring logs)
- Two previous verifications (Attach boring logs)
- Not applicable (Holding tank(s), no drainfield)
- Unable to verify (See Comments/Explanation)
- Other (See Comments/Explanation)

**Comments/Explanation:**

**Indicate depths or elevations**

A. Bottom of distribution media	101.8
B. Periodically saturated soil/bedrock	98.3
C. System separation	3.5
D. Required compliance separation*	3.0

\*May be reduced up to 15 percent if allowed by Local Ordinance.

**Any "no" answer above indicates the system is failing to protect groundwater.**

**5. Operating Permit and Nitrogen BMP\* – Compliance component #5 of 5**  Not applicable

Is the system operated under an Operating Permit?  Yes  No **If "yes", A below is required**

Is the system required to employ a Nitrogen BMP?  Yes  No **If "yes", B below is required**

BMP = Best Management Practice(s) specified in the system design

**If the answer to both questions is "no", this section does not need to be completed.**

**Compliance criteria**

a. Operating Permit number: _____ Have the Operating Permit requirements been met?	<input type="checkbox"/> Yes <input type="checkbox"/> No
b. Is the required nitrogen BMP in place and properly functioning?	<input type="checkbox"/> Yes <input type="checkbox"/> No

**Any "no" answer indicates Noncompliance.**

**Upgrade Requirements** (Minn. Stat. § 115.55) An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, repaired, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.

# Service Order

Service Order #: 82062

Olson's Sewer Service, Inc. 17638 Lyons Street N.E. Forest Lake, MN 55025 651-464-2082

Date:  Preferred Time:  Important Note: **Road Restrictions (Tons)**

Addr: **9080 170th Street North**  
 Name: **Dave & Dana Olmstead** C1: (612) 802-5483 Dana  
 City: **Hugo, MN 55038** C2: (651) 895-7713 Dave  
 Cty: **Washington**  
 Twp:

JH must do for compliance inspection please.750 put in shop tank; verify it went to Metro

Driving Dir						
Tank Type	Pre-cast	PreT	T1	T1C	T2	T3
Treatment Type	Mound System	Sizes:	1250		1000	1000
Treatment Area	600Sq Ft	Depth to MH:	Grade	I	Grade	C
	1	Riser Feet:				Grade
Dist to Lift Tank		LS Outlet to Bottom:				

Water Meter		Power Disconnect at Lift	<input type="checkbox"/>			
Effluent Filter		Looped	<input type="checkbox"/>			
Two Techs		# Bedrooms				
City Sewer	N	Pump Breaker				
Install Date	7/6/2005	<b>Baseline Equal Dist Hgt</b>				
Installer	Brott Excavating	1	4			
As Built	W. 1285	2	5			
Cleanout		3	6			
Lift Pump	40 gpm @18 feet of head 125-150 gals per cycle					

Service Type	Last Service Date	Mobilize Time	At Site Time	Complete Time	Disposal Time	Leave Disposal Time
1 Lift Station Maintenance		11:00 AM	11:45 AM	1:00 PM		
2 Maintenance Pumping	4/25/2014					
3 Compliance Inspection						
4 LUG Permit	4/25/2014					

Time Dosing	<input type="checkbox"/>	Iron Filter	<input type="checkbox"/>	S&E Quality	<input type="checkbox"/>	Eq Dist Hgt 1			
Lint Filter	<input type="checkbox"/>	Sump Pump	<input type="checkbox"/>	PH Reading	<input type="checkbox"/>	2		Event/Cycle Ctr	<input type="text"/>
Switch Tree	<input type="checkbox"/>	Ejector Pump	<input type="checkbox"/>	Non Dom Wastes	<input type="checkbox"/>	3		Elapsed Time	<input type="text"/>
Event Counter	<input type="checkbox"/>	Mgmt Plan	<input type="checkbox"/>	TA Visual Insp	<input type="checkbox"/>	4		Time Dosing	<input type="text"/>
Garbage Disp.	<input type="checkbox"/>	Monitoring	<input type="checkbox"/>			5		Water Meter	<input type="text"/>
Water Softener	<input type="checkbox"/>	Irrigation	<input type="checkbox"/>			6			

<b>Dump Site</b>	<b>Gal Pumped</b>	CSR	Liz	Reminder	5/22/2020
Harris	1750	Garden Hose	<input type="checkbox"/>	Lift Station Last Service	
Metro	800	FollowUp	<input type="checkbox"/>	Vehicle	15
<b>Total:</b>	<b>2550</b>	Sewage Type Disposed	<input checked="" type="checkbox"/>	Service Person	JH
		Amt Billed	537.00	Payment Type	CC on file
				Inv #	11135

## Logs of Soil Borings

Location of Project: 9080 170th St N Hugo, MN 55038

Borings Made by Ben Zierke

Date: 5/18/2017

Hand bucket auger used for borings; USDA - SCS Soil Classification used.

Depth, in Inches	Boring Number 1	Depth, in Inches	Boring Number 2
0-----	-----	0-----	-----
0-12"	10YR 3/3 sandy loam	0-14"	Loamy fill
12-18"	10YR 5/4 sandy loam, 20% coarse fragments	14-20"	10YR 3/3 sandy loam
18-24"	10YR 5/4 clay loam, redox present below 20"	20-28"	10YR 5/4 clay loam, redox present below 22"

End of boring at 2 feet  
**Standing water table:**  
 Present at \_\_\_\_\_ feet of depth \_\_\_\_\_ Hours after boring  
 Standing water not present in hole   
**Mottled Soil:**  
 Observed at 1.7 feet of depth  
 Mottled soil not present in bore hole   
 Comments:

End of boring at 2.3 feet  
**Standing water table:**  
 Present at \_\_\_\_\_ feet of depth \_\_\_\_\_ Hours after boring  
 Standing water not present in hole   
**Mottled Soil:**  
 Observed at 1.9 feet of depth  
 Mottled soil not present in bore hole   
 Comments:

Depth, in Inches	Boring Number 3	Depth, in Inches	Boring Number 4
0-----	-----	0-----	-----


End of boring at \_\_\_\_\_ feet  
**Standing water table:**  
 Present at \_\_\_\_\_ feet of depth \_\_\_\_\_ Hours after boring  
 Standing water not present in hole   
**Mottled Soil:**  
 Observed at \_\_\_\_\_ feet of depth  
 Mottled soil not present in bore hole   
 Comments:

End of boring at \_\_\_\_\_ feet  
**Standing water table:**  
 Present at \_\_\_\_\_ feet of depth \_\_\_\_\_ Hours after boring  
 Standing water not present in hole   
**Mottled Soil:**  
 Observed at \_\_\_\_\_ feet of depth  
 Mottled soil not present in bore hole   
 Comments:

4/2015  
1991 2016

**Relative Elevations (in feet)**

B1: 100.0, redox 98.3
B2: 98.6, redox 96.7
Bottom of rock: 101.8
B1 Separation: 3.5
B2 Separation: 5.1
Benchmark: 96.3 (manhole cover on lift station)
Height of instrument: 105.6



Imagery Date: 10/11/2014 45°11'48.29" N 92°55'20.04" W elev 981 ft eye alt 1248 ft

Google Earth