



Minnesota Pollution Control Agency

520 Lafayette Road North
St. Paul, MN 55155-4194

Compliance Inspection Form

Existing Subsurface Sewage Treatment Systems (SSTS)

Doc Type: Compliance and Enforcement

Madd to Nancy
15 July 17

Inspection results based on Minnesota Pollution Control Agency (MPCA) requirements and attached forms - additional local requirements may also apply.

Submit completed form to Local Unit of Government (LUG) and system owner within 15 days

For local tracking purposes:

System Status

System status on date (mm/dd/yyyy): 12 July 17

[X] Compliant - Certificate of Compliance
(Valid for 3 years from report date, unless shorter time frame outlined in Local Ordinance.)

[ ] Noncompliant - Notice of Noncompliance
(See Upgrade Requirements on page 3.)

Reason(s) for noncompliance (check all applicable)

- [ ] Impact on Public Health (Compliance Component #1) - Imminent threat to public health and safety
[ ] Other Compliance Conditions (Compliance Component #3) - Imminent threat to public health and safety
[ ] Tank Integrity (Compliance Component #2) - Failing to protect groundwater
[ ] Other Compliance Conditions (Compliance Component #3) - Failing to protect groundwater
[ ] Soil Separation (Compliance Component #4) - Failing to protect groundwater
[ ] Operating permit/monitoring plan requirements (Compliance Component #5) - Noncompliant

Property Information

Parcel ID# or Sec/Twp/Range:

Property address: 14766 110th St. S., Hastings, MN 55035 Reason for inspection: Routine

Property owner: Nancy Bailey Owner's phone: 651-398-4324

Owner's representative: Representative phone:

Local regulatory authority: Denmark Township Regulatory authority phone:

Brief system description: 2 Septic tanks a drainfield

Comments or recommendations:

Certification

I hereby certify that all the necessary information has been gathered to determine the compliance status of this system. No determination of future system performance has been nor can be made due to unknown conditions during system construction, possible abuse of the system, inadequate maintenance, or future water usage.

Inspector name: Bob Freiermuth Certification number: C818

Business name: Bob Freiermuth Santitation, LLC License number: L492

Inspector signature: [Signature] Phone number: 651-437-5566

Necessary or Locally Required Attachments

- [X] Soil boring logs [X] System/As-built drawing [ ] Forms per local ordinance

[ ] Other information (list):



Property address: 14766 110th St. S., Hastings, MN 55033

Inspector initials/Date

BT 12 July 17  
(mm/dd/yyyy)

### 1. Impact on Public Health – Compliance component #1 of 5

#### Compliance criteria:

System discharges sewage to the ground surface.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
System discharges sewage to drain tile or surface waters.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
System causes sewage backup into dwelling or establishment.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

**Any "yes" answer above indicates the system is an imminent threat to public health and safety.**

Comments/Explanation:

#### Verification method(s):

- Searched for surface outlet
- Searched for seeping in yard/backup in home
- Excessive ponding in soil system/D-boxes
- Homeowner testimony (See Comments/Explanation)
- "Black soil" above soil dispersal system
- System requires "emergency" pumping
- Performed dye test
- Unable to verify (See Comments/Explanation)
- Other methods not listed (See Comments/Explanation)

### 2. Tank Integrity – Compliance component #2 of 5

#### Compliance criteria:

System consists of a seepage pit, cesspool, drywell, or leaching pit. <i>Seepage pits meeting 7080.2550 may be compliant if allowed in local ordinance.</i>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Sewage tank(s) leak below their designed operating depth. If yes, which sewage tank(s) leaks:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

**Any "yes" answer above indicates the system is failing to protect groundwater.**

Comments/Explanation:

Pumped By Schlomka Ser. (OK)  
See Attached

#### Verification method(s):

- Probed tank(s) bottom
- Examined construction records
- Examined Tank Integrity Form (Attach)
- Observed liquid level below operating depth
- Examined empty (pumped) tanks(s)
- Probed outside tank(s) for "black soil"
- Unable to verify (See Comments/Explanation)
- Other methods not listed (See Comments/Explanation)

### 3. Other Compliance Conditions – Compliance component #3 of 5

- a. Maintenance hole covers are damaged, cracked, unsecured, or appear to be structurally unsound.  Yes\*  No  Unknown
- b. Other issues (electrical hazards, etc.) to immediately and adversely impact public health or safety.  Yes\*  No  Unknown
- \*System is an imminent threat to public health and safety.**

Explain:

- c. System is non-protective of ground water for other conditions as determined by inspector.  Yes\*  No
- \*System is failing to protect groundwater.**

Explain:

Property address: 14766 110th ST S HASTINGS

Inspector initials/Date: BT 12 July 17  
(mm/dd/yyyy)

#### 4. Soil Separation – Compliance component #4 of 5

Date of installation: 09-22-1994  Unknown  
(mm/dd/yyyy)

Shoreland/Wellhead protection/Food beverage lodging?  Yes  No

##### Compliance criteria:

For systems built prior to April 1, 1996, and not located in Shoreland or Wellhead Protection Area or not serving a food, beverage or lodging establishment:  Yes  No

Drainfield has at least a two-foot vertical separation distance from periodically saturated soil or bedrock.

Non-performance systems built April 1, 1996, or later or for non-performance systems located in Shoreland or Wellhead Protection Areas or serving a food, beverage, or lodging establishment:  Yes  No

Drainfield has a three-foot vertical separation distance from periodically saturated soil or bedrock.\*

"Experimental", "Other", or "Performance" systems built under pre-2008 Rules; Type IV or V systems built under 2008 Rules (7080.2350 or 7080.2400 (Advanced Inspector License required)  Yes  No

Drainfield meets the designed vertical separation distance from periodically saturated soil or bedrock.

##### Verification method(s):

Soil observation does not expire. Previous soil observations by two independent parties are sufficient, unless site conditions have been altered or local requirements differ.

- Conducted soil observation(s) (Attach boring logs)
- Two previous verifications (Attach boring logs)
- Not applicable (Holding tank(s), no drainfield)
- Unable to verify (See Comments/Explanation)
- Other (See Comments/Explanation)

##### Comments/Explanation:

B1  
1-24" 10YR 2/6 Clay Loam  
29" 32 10YR 7/4 SILTY LOAM  
32.55" 10YR 5/6 SANDY LOAM

##### Indicate depths or elevations

A. Bottom of distribution media	<u>24"</u>
B. Periodically saturated soil/bedrock	<u>55" STOP BORE</u>
C. System separation	<u>31"</u>
D. Required compliance separation*	<u>24"</u>

\*May be reduced up to 15 percent if allowed by Local Ordinance.

Any "no" answer above indicates the system is failing to protect groundwater.

#### 5. Operating Permit and Nitrogen BMP\* – Compliance component #5 of 5 Not applicable

Is the system operated under an Operating Permit?  Yes  No If "yes", A below is required

Is the system required to employ a Nitrogen BMP?  Yes  No If "yes", B below is required

BMP = Best Management Practice(s) specified in the system design

If the answer to both questions is "no", this section does not need to be completed.

##### Compliance criteria

- a. Operating Permit number: \_\_\_\_\_  Yes  No  
Have the Operating Permit requirements been met?
- b. Is the required nitrogen BMP in place and properly functioning?  Yes  No

Any "no" answer indicates Noncompliance.

**Upgrade Requirements** (Minn. Stat. § 115.55) An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, repaired, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.



Reporting Information

Date of maintenance: 9-23-16 Reason for maintenance: reg. Maint.
Property address: 14766 110th St S City: Hastings State: MN Zip: 55033
Property owner's name: Brightbill
Property-owner's address if different:
City: State: Zip: Phone: Fax:

- 1. Access used to remove septage: [X] Maintenance hole [ ] Other (Go to #3 below)
2. If maintenance hole was used, were all covers securely replaced? [X] Yes [ ] No please explain
Explanation:
3. If owner refuses to allow a Subsurface Sewage Treatment System (SSTS) to be pumped through the maintenance hole, have them complete and sign the following statement.
I, (Owner's name), refuse to allow the removal of the solids and liquids through the maintenance hole. I understand that removal of solids and liquids through other access points is not considered maintenance.
Owner's signature: Date:

4. Is the tank designed as a leaky tank? (Example: seepage pit, cesspool, drywell, leaching pit)
Tank #1: [ ] Yes [X] No Verification method used?
Tank #2: [ ] Yes [X] No Verification method used?


5. Is there evidence of tank leakage from a septic, holding, pretreatment or pump tank below the operating depth or evidence of damaged, cracked or structurally unsound maintenance hole covers?
Table with columns: Tank, Leaking out, Leaking in, Cover damage. Rows: Septic/holding Tank #1, Septic/holding Tank #2, Pretreatment Tank, Pump Tank.

6. How many gallons of septage were removed?
Tank #1: 1000 Tank #2: 1000 Pretreatment Tank: Pump Tank:

7. Is there any sensory (smell and/or sight) evidence of non-domestic wastes?
[ ] Yes [X] No Please explain:
Disposal site: [X] Wastewater treatment plant [ ] Land application [ ] Other (please explain below)
Explanation:
List any troubleshooting, minor repairs conducted, tank safety\* concerns or other concerns:

8. Certification: I hereby certify as a State of Minnesota-certified SSTS Maintainer that I personally conducted the work and made the observations, or directly supervised others in the performance of this job.

Maintainer's name and address: Schlomka Services
License #: 2989 Maintainer's phone: 651 459 3718
Signature: Date: June, 19, 2017



Date:

12 July 17

Customer Name:

Nancy Bailey

Street Address:

14766 110th St. S.

City, State, Zip:

Hastings, MN 55033

Phone Number:

651-398-4324

### COMPANY DISCLAIMER

Based on what we were able to observe and on our experience with on-site wastewater technology, we submit this Onsite Sewage Treatment System Inspection Report based on the present condition of the onsite sewage disposal system.

*Bob Freiermuth* has not been retained to warrant, guarantee, or certify the proper functioning of the system for any period of time in the future. Because of the numerous factors (usage, soil characteristics, previous failures, etc.) which may affect the proper operation of a septic system, as well as the inability of our company to supervise or monitor the use or maintenance of the system, this report shall not be construed as a warranty by our company that the system will function properly for any particular buyer. *Bob Freiermuth* hereby DISCLAIMS ANY WARRANTY, either expressed or implied, arising from the inspection of the septic system or this report. We are also not ascertaining any affect the system is having on the groundwater.

Inspecting Company

Phone

651-437-5566 (Office)

Bob Freiermuth Sanitation, LLC

License No.

818

Owners signature:

I have studied the information contained herein and certify that my assessment is honest, thorough, and to the best of my ability, correct.

Name:

*Bob Freiermuth*

Title:

SSTS Inspector 818

12 July 17

