

## SSTS MAINTENANCE REPORT

Date of Maintenance 7-28-17 Reason for Maintenance: Regular  
 Property Address: 9424 186<sup>th</sup> St N Property Owner's Name: Gary Thomson  
 Municipality: Forest Lake State MN Zip Code 55025 GEO Code/Property I.D. #: g2201m7496

What was done to the system?	Tank Measurements (must be completed if tanks NOT pumped)
<input checked="" type="checkbox"/> Tank(s) Pumped <input type="checkbox"/> Sludge and scum measured. Do tanks need to be pumped? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements)	Liquid Level of Tank _____ in. Sludge Level _____ in. Scum Level _____ in. Total (Sludge + Scum) _____ / Liquid Level _____ = % Sludge & Scum _____ *

1. Access used to remove septage:  Maintenance Hole  Other (Go to #3 below) \* Tank must be pumped if this value is greater than 25%.
2. If maintenance hole was used, were all covers securely replaced?  Yes  No **please explain**
- Explanation: \_\_\_\_\_

**3. If owner refuses to allow a Subsurface Sewage Treatment System (SSTS) to be pumped through the maintenance hole, have them complete and sign the following statement:**

I, \_\_\_\_\_ (owner's name), refuse to allow the removal of solids and liquids through the maintenance hole. I understand that removal of solids and liquids through other access points is not considered maintenance.

**4. Is the tank designed as a leaky tank? example: seepage pit, cesspool, drywell, leaching pit**

Tank#1  Yes  No Verification Method Used: \_\_\_\_\_

Tank#2  Yes  No Verification Method Used: \_\_\_\_\_

**5. Is there evidence of tank leakage from a septic, holding, pretreatment or pump tank below the operating depth or evidence of damaged, cracked, or structurally unsound maintenance hole covers?**

Tank	Leaking Out	Leaking In	Cover Damage
Septic/Holding Tank #1	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Septic/Holding Tank #2	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Pretreatment Tank	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Pump Tank	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No

**6. How many gallons of septage were removed?**

Tank #1 1700 Tank #2 \_\_\_\_\_ Pretreatment Tank \_\_\_\_\_ Pump Tank \_\_\_\_\_

**7. Other information: List any troubleshooting, minor repairs conducted, tank safety concerns, or other concerns.**

**8. Certification:** I hereby certify as a State of Minnesota certified SSTS Maintainer that I personally conducted the work and made the observations, or directly supervised others in the performance of this job.

Maintainer's Name: OSSI Maintainer's Address: 17638 Lyons St NE

Maintainer's License #: 216 Maintainer's Phone #: \_\_\_\_\_

Maintainer's Signature: \_\_\_\_\_ Date: 7-28-17

## SSTS MAINTENANCE REPORT

Date of Maintenance 7/31/17 Reason for Maintenance: Maintenance - 3 year  
 Property Address: 14035 Oldfield Road N. Property Owner's Name: John Adams  
 Municipality: May Twp./Stillwater State MN Zip Code 55082 GEO Code/Property I.D. #: \_\_\_\_\_

What was done to the system?	Tank Measurements (must be completed if tanks NOT pumped)
<input checked="" type="checkbox"/> Tank(s) Pumped <input type="checkbox"/> Sludge and scum measured. Do tanks need to be pumped? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements)	Liquid Level of Tank _____ in. Sludge Level _____ in. Scum Level _____ in. Total (Sludge + Scum) _____ / Liquid Level _____ = % Sludge & Scum _____ *

1. Access used to remove septage:  Maintenance Hole  Other (Go to #3 below) \* Tank must be pumped if this value is greater than 25%.
2. If maintenance hole was used, were all covers securely replaced?  Yes  No *please explain*

Explanation: \_\_\_\_\_

**3. If owner refuses to allow a Subsurface Sewage Treatment System (SSTS) to be pumped through the maintenance hole, have them complete and sign the following statement:**

I, \_\_\_\_\_ (owner's name), refuse to allow the removal of solids and liquids through the maintenance hole. I understand that removal of solids and liquids through other access points is not considered maintenance.

**4. Is the tank designed as a leaky tank? example: seepage pit, cesspool, drywell, leaching pit**

Tank#1  Yes  No Verification Method Used: Pumping  
 Tank#2  Yes  No Verification Method Used: \_\_\_\_\_

**5. Is there evidence of tank leakage from a septic, holding, pretreatment or pump tank below the operating depth or evidence of damaged, cracked, or structurally unsound maintenance hole covers?**

Tank	Leaking Out	Leaking In	Cover Damage
Septic/Holding Tank #1	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Septic/Holding Tank #2	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Pretreatment Tank	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Pump Tank	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No

**6. How many gallons of septage were removed?**

Tank #1 1060 Tank #2 \_\_\_\_\_ Pretreatment Tank \_\_\_\_\_ Pump Tank \_\_\_\_\_

**7. Other information: List any troubleshooting, minor repairs conducted, tank safety concerns, or other concerns.**

**8. Certification:** I hereby certify as a State of Minnesota certified SSTS Maintainer that I personally conducted the work and made the observations, or directly supervised others in the performance of this job.

Maintainer's Name: Olson's Sewer Service Maintainer's Address: 17638 Lyons Street NW Forest Lake

Maintainer's License #: 216 Maintainer's Phone #: 651-464-2082

Maintainer's Signature:  Date: 7-31-17



19

**DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT**  
**GOVERNMENT CENTER**  
 14949 62nd STREET NORTH P.O. BOX 6 STILLWATER, MN 55082-0006  
 Office: 651-430-6655 TDD: 651-430-6246 FAX: 651-430-6730

**SSTS MAINTENANCE REPORT**

Date of Maintenance 7/27/17 Reason for Maintenance: pump replacement  
 Property Address: 6475 132nd Street N. Property Owner's Name: Douglas Hoppe  
 Municipality: Hugo State MN Zip Code 55038 GEO Code/Property I.D. #: 1891397497

What was done to the system?	Tank Measurements (must be completed if tanks NOT pumped)
<input checked="" type="checkbox"/> Tank(s) Pumped <input type="checkbox"/> Sludge and scum measured. Do tanks need to be pumped? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements)	Liquid Level of Tank _____ in. Sludge Level _____ in. Scum Level _____ in. Total (Sludge + Scum) _____ / Liquid Level _____ = % Sludge & Scum _____ *

1. Access used to remove septage:  Maintenance Hole  Other (Go to #3 below) \* Tank must be pumped if this value is greater than 25%  
 2. If maintenance hole was used, were all covers securely replaced?  Yes  No **please explain**

Explanation: \_\_\_\_\_

**3. If owner refuses to allow a Subsurface Sewage Treatment System (SSTS) to be pumped through the maintenance hole, have them complete and sign the following statement:**

I, \_\_\_\_\_ (owner's name), refuse to allow the removal of solids and liquids through the maintenance hole. I understand that removal of solids and liquids through other access points is not considered maintenance.

**4. Is the tank designed as a leaky tank? example: seepage pit, cesspool, drywell, leaching pit**

Tank#1  Yes  No Verification Method Used: \_\_\_\_\_  
 Tank#2  Yes  No Verification Method Used: \_\_\_\_\_

**5. Is there evidence of tank leakage from a septic, holding, pretreatment or pump tank below the operating depth or evidence of damaged, cracked, or structurally unsound maintenance hole covers?**

Tank	Leaking Out	Leaking In	Cover Damage
Septic/Holding Tank #1	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Septic/Holding Tank #2	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Pretreatment Tank	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Pump Tank	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

**6. How many gallons of septage were removed?**

Tank #1 1000 Tank #2 1000 Pretreatment Tank \_\_\_\_\_ Pump Tank 600

**7. Other information: List any troubleshooting, minor repairs conducted, tank safety concerns, or other concerns.**

**8. Certification:** I hereby certify as a State of Minnesota certified SSTS Maintainer that I personally conducted the work and made the observations, or directly supervised others in the performance of this job.

Maintainer's Name: Olson's Sewer Service Maintainer's Address: 17638 Lyons Street NE

Maintainer's License #: 216 Maintainer's Phone #: 651-464-2082

Maintainer's Signature \_\_\_\_\_ Date: 7/27/17

A

## SSTS MAINTENANCE REPORT

Date of Maintenance 7/31/17 Reason for Maintenance: Maintenance Pumping  
 Property Address: 23955 Hawthorne Ave N Property Owner's Name: Scott Smith  
 Municipality: Forest Lake State MN Zip Code 55025 GEO Code/Property I.D. #: 6979007499

What was done to the system?	Tank Measurements (must be completed if tanks NOT pumped)
<input checked="" type="checkbox"/> Tank(s) Pumped <input type="checkbox"/> Sludge and scum measured. Do tanks need to be pumped? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements)	Liquid Level of Tank _____ in.   Sludge Level _____ in.   Scum Level _____ in. Total (Sludge + Scum) _____ / Liquid Level _____ = % Sludge & Scum _____ *

1. Access used to remove septage:  Maintenance Hole    Other (Go to #3 below)      \* Tank must be pumped if this value is greater than 25%.
2. If maintenance hole was used, were all covers securely replaced?  Yes    No **please explain**

Explanation: \_\_\_\_\_

**3. If owner refuses to allow a Subsurface Sewage Treatment System (SSTS) to be pumped through the maintenance hole, have them complete and sign the following statement:**

I, \_\_\_\_\_ (owner's name), refuse to allow the removal of solids and liquids through the maintenance hole. I understand that removal of solids and liquids through other access points is not considered maintenance.

**4. Is the tank designed as a leaky tank? example: seepage pit, cesspool, drywell, leaching pit**

Tank#1    Yes    No   Verification Method Used: Pumping  
 Tank#2    Yes    No   Verification Method Used: Pumping

**5. Is there evidence of tank leakage from a septic, holding, pretreatment or pump tank below the operating depth or evidence of damaged, cracked, or structurally unsound maintenance hole covers?**

Tank	Leaking Out	Leaking In	Cover Damage
Septic/Holding Tank #1	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Septic/Holding Tank #2	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Pretreatment Tank	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Pump Tank	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

**6. How many gallons of septage were removed?**

Tank #1 1000   Tank #2 1000   Pretreatment Tank \_\_\_\_\_   Pump Tank 606

**7. Other information: List any troubleshooting, minor repairs conducted, tank safety concerns, or other concerns.**

**8. Certification:** I hereby certify as a State of Minnesota certified SSTS Maintainer that I personally conducted the work and made the observations, or directly supervised others in the performance of this job.

Maintainer's Name: Olson's Sewer Service   Maintainer's Address: 17638 Lyons Street NE

Maintainer's License #: 26   Maintainer's Phone #: 651-464-2082

Maintainer's Signature: [Signature]   Date: 7/31/17



*pd*

## SSTS MAINTENANCE REPORT

Date of Maintenance 7/31/17 Reason for Maintenance: Maintenance pumping  
 Property Address: 23110 Hasca Ave Property Owner's Name: Eric Youngner  
 Municipality: Forestlake State MN Zip Code 55025 GEO Code/Property I.D. #: C314227498

What was done to the system?	Tank Measurements (must be completed if tanks NOT pumped)
<input checked="" type="checkbox"/> Tank(s) Pumped <input type="checkbox"/> Sludge and scum measured. Do tanks need to be pumped? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements)	Liquid Level of Tank _____ in. Sludge Level _____ in. Scum Level _____ in. Total (Sludge + Scum) _____ / Liquid Level _____ = % Sludge & Scum _____ *

1. Access used to remove septage:  Maintenance Hole  Other (Go to #3 below) \* Tank must be pumped if this value is greater than 25%.  
 2. If maintenance hole was used, were all covers securely replaced?  Yes  No **please explain**

Explanation: \_\_\_\_\_

**3. If owner refuses to allow a Subsurface Sewage Treatment System (SSTS) to be pumped through the maintenance hole, have them complete and sign the following statement:**

I, \_\_\_\_\_ (owner's name), refuse to allow the removal of solids and liquids through the maintenance hole. I understand that removal of solids and liquids through other access points is not considered maintenance.

**4. Is the tank designed as a leaky tank? example: seepage pit, cesspool, drywell, leaching pit**

Tank#1  Yes  No Verification Method Used: Pumping  
 Tank#2  Yes  No Verification Method Used: Pumping

**5. Is there evidence of tank leakage from a septic, holding, pretreatment or pump tank below the operating depth or evidence of damaged, cracked, or structurally unsound maintenance hole covers?**

Tank	Leaking Out	Leaking In	Cover Damage
Septic/Holding Tank #1	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Septic/Holding Tank #2	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Pretreatment Tank	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Pump Tank	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

**6. How many gallons of septage were removed?**

Tank #1 1000 Tank #2 1000 Pretreatment Tank 204 Pump Tank \_\_\_\_\_

**7. Other information: List any troubleshooting, minor repairs conducted, tank safety concerns, or other concerns.**

**8. Certification:** I hereby certify as a State of Minnesota certified SSTS Maintainer that I personally conducted the work and made the observations, or directly supervised others in the performance of this job.

Maintainer's Name: Olson's Sewer Service Maintainer's Address: 17638 Lyons Street NE

Maintainer's License #: 216 Maintainer's Phone #: 651-464-2082

Maintainer's Signature: [Signature] Date: 7/31/17